

ENVIRONMENTAL COMPLIANCE APPROVAL

NUMBER 2846-C5TQLR

Issue Date: September 10, 2021

2775980 Ontario Incorporated
2500 Williams Pky, No. 34
Brampton, Ontario
L6S 5M9

Site Location: 2775980 Ontario Inc. - Pet Crematorium
2500 Williams Pky
Brampton City, Regional Municipality of Peel
L6S 5M9

You have applied under section 20.2 of Part II.1 of the Environmental Protection Act, R.S.O. 1990, c. E. 19 (Environmental Protection Act) for approval of:

- two (2) natural gas fired cremation units (Saniflame 300-P Gasifer), each to process up to 45.3 kilograms per hour and up to 1,088 kilograms per day of Non-Infectious Remains of Companion Pets, both units discharging into the air at a minimum nominal volumetric flow rate of 2.54 actual cubic metres per second (when both operating at the same time) at an approximate temperature of 1,000 degrees Celsius, through a common stack (Source INCIN), each operating at a minimum combustion temperature of 1,000 degrees Celsius and a minimum 1 second retention time in the secondary chamber, each equipped with a computer monitoring system, including temperature monitoring and recording in the secondary chamber, each consisting of:
 - a. a primary combustion chamber, equipped with a natural gas fired burner, having a maximum heat input of 1,266,000 kilojoules per hour;
 - b. a secondary combustion chamber, each equipped with a natural gas fired burner, having a maximum heat input of 1,266,000 kilojoules per hour;
- one (1) stack (Source INCIN), equipped with CEM system to monitor and record temperature, oxygen and carbon monoxide, having an exit diameter of 0.3 metre, extending 7.7 metres above the roof and 12.7 metres above grade;

- one (1) granulator, controlled by the hood and a charcoal filter, discharging into the atmosphere at a nominal volumetric flow rate of 0.12 actual cubic metre per second through a stack (Source GRAN), having an exit diameter of 0.10 metre, extending 0.9 metre above the roof and 5.9 metres above grade;
- one (1) laser engraver (Source LASER), used for urns etching at the maximum processing rates of 20 urns per day;

all in accordance with the Environmental Compliance Approval Application submitted 2775980 Ontario Incorporated, dated March 24, 2021 and signed by Chetal Vichare; two letters (email) from Terri-Lyn Rooke (RWDI) dated August 12, 2021,; the letter (email) from Chetal Vichare dated September 8, 2021 and all supporting information associated with the application.

For the purpose of this environmental compliance approval, the following definitions apply:

1. "Approval" means this Environmental Compliance Approval, including the application and supporting documentation listed above;
2. "CEM System" means the continuous emission monitoring system consisting of continuous monitors and recording devices;
3. "Companion Pets" means animals that were kept by humans for company, amusement or psychological support;
4. "Company" means 2775980 Ontario Incorporated, that is responsible for the construction or operating of the Facility and includes any successors and assigns;
5. "Director" means a person appointed by the Minister pursuant to section 5 of the EPA;
6. "District Manager" means the appropriate local district office of the Ministry, where the Facility is geographically located;
7. "EPA" means the Environmental Protection Act, R.S.O. 1990, c.E.19, as amended;
8. "Equipment" means the two (2) pet cremation units described in the Company's application, this Approval and in the supporting documentation submitted with the application, to the extent approved by this Approval;
9. "ESDM Report" means the Emission Summary and Dispersion Modelling Report prepared in accordance with section 26 of . O.Reg. 419/05 and the Procedure Document by Bryce Dawson (RWDI Air Inc.) and dated April 6, 2021 submitted in support of the application including the email from Terri-Lyn Rooke (RWDI) dated August 12, 2021 and any addendum submissions made during the Ministry's review of the Company's application;

10. "Exhausted" means the capacity of the Equipment to adsorb emissions is reached and the Equipment is no longer able to effectively reduce emissions;
11. "Facility" means the entire operation located on the property where the Equipment is located;
12. "Infectious Substance" means, a disease listed in,
 - a. Schedule VII of the Health of Animals Regulations made under the Health of Animals Act (Canada) as amended, or
 - b. the Reportable Diseases Regulations made under the Health of Animals Act (Canada) as amended;
13. "Manager" means the Manager, Technology Standards Section, Standards Development Branch, or any other person who represents and carries out the duties of the Manager, Technology Standards Section, Standards Development Branch, as those duties relate to the conditions of this Approval;
14. "Manual" means a document or a set of documents that provide written instructions to staff of the Company;
15. "Ministry" means the ministry of the government of Ontario responsible for the EPA and includes all officials, employees or other persons acting on its behalf;
16. "Non-Infectious Remains of Companion Pets" means whole carcasses or parts from carcasses of Companion Pets and are not contaminated with any Infectious Substance;
17. "O. Reg. 419" means the Ontario Regulation 419/05, Air Pollution – Local Air Quality, as amended;
18. "Point of Impingement" has the same meaning as in section 2 of O. Reg. 419;
19. "Pre-Test Plan" means a plan for the Source Testing including the information required in Section 5 of the Source Testing Code;
20. "Publication NPC-300" means the Ministry Publication NPC-300, "Environmental Noise Guideline, Stationary and Transportation Sources – Approval and Planning, Publication NPC-300", August 2013, as amended;
21. "Report EPS 1/PG/7" means the document titled "Protocols and Performance Specifications for Continuous Monitoring of Gaseous Emissions from Thermal Power Generation - Report EPS 1/PG/7" published by Environment Canada in December 2005, as modified;

22. "Source Testing" means sampling and testing to measure emissions resulting from operating the Equipment under conditions which yield the worst case emissions, as practically possible, within the approved operating range of the Equipment and satisfies paragraph 1 of subsection 11(1) of O. Reg. 419, as determined in consultation with the Manager;
23. "Source Testing Code" means the Ontario Source Testing Code, dated June 2010, prepared by the Ministry, as amended;
24. "Targeted Sources" means two (2) cremation units operating at the same time at the nominal loading rate; and
25. "Test Contaminants" means the contaminants listed in Schedule "B".

You are hereby notified that this environmental compliance approval is issued to you subject to the terms and conditions outlined below:

TERMS AND CONDITIONS

1. PERFORMANCE REQUIREMENTS

1. The Company shall ensure that the design and operation of the Equipment comply with the following limits:
 - a. The concentration of organic matter in the combustion gases leaving the Equipment, expressed as equivalent methane, being an average of ten measurements taken at approximately one minute intervals, shall not exceed 100 parts per million by volume, on an undiluted basis;
 - b. The concentration of oxygen in the undiluted flue gas, as recorded by the CEM System, shall not be less than 6 percent by volume on a dry basis, calculated as a ten minute average;
 - c. the half-hour average concentration of carbon monoxide in the undiluted flue gases, as recorded by the CEM System, shall not exceed 100 parts per million by volume, on a dry basis normalized to 11 percent oxygen at a reference temperature of 25 degrees Celsius and a reference pressure of 101.3 kilopascals; and
 - d. The operating temperature in the each secondary chamber of the Equipment, as recorded by the CEM System, shall not be less than 1,000 degrees Celsius at all times when the primary chamber is loaded and incineration is in progress.

2. OPERATION AND MAINTENANCE

1. The Company shall ensure that the Equipment is properly operated and maintained at all times.
The Company shall:
 - a. prepare, prior to the commencement of operation of the Equipment and update, as necessary, a Manual outlining the operating procedures and a maintenance program for the Equipment, including as a minimum:
 - i. procedures to ensure that only Non-Infectious Remains of Companion Pets are processed in the Equipment;
 - ii. operating and maintenance procedures in accordance with good engineering practice, including annual inspection procedures as recommended by the Equipment and CEM System suppliers;
 - iii. emergency procedures;
 - iv. procedures to control all discharges from the Equipment in the event of loss or failure of power source to the Equipment;
 - v. procedures for any record keeping activities relating to the operation and maintenance of the Equipment and the CEM System;
 - vi. procedures for operator training which is to be provided by an individual experienced with the Equipment;
 - vii. procedures for recording and responding to complaints regarding the operation of the Equipment;
 - viii. all appropriate measures to minimize noise, fugitive dust and odorous emissions from all potential sources at the Facility; and
 - b. implement the recommendations of the Manual.
2. The Company shall operate the Equipment in accordance with the following procedures:
 - a. The burner flame in the each secondary chamber shall be established before the primary chamber is fired.
 - b. The temperature in the each secondary chamber, as measured by the CEM System, shall be maintained at minimum of 1,000 degrees Celsius at all times when the primary chamber is loaded and incineration is in progress.
 - c. The burner in the primary chamber shall shut off automatically if the secondary chamber burner fails.

3. The Company shall ensure that only Non-Infectious Remains of Companion Pets are burned in the Equipment.
4. The Company shall ensure that the charcoal filter in the Equipment is replaced before it is Exhausted.

3. SOURCE TESTING

1. The Company shall perform Source Testing in accordance with the procedure outlined in Schedule "A", to determine the rate of emission of Total Suspended Particulate Matter and Total Hydrocarbon Compounds Matter from the the Targeted Sources.
2. In the event that the results of the Source Testing required by Condition 3.1 indicate that the concentration of Total Suspended Particulate Matter in the undiluted gas emitted from the Targeted Sources exceeds 20 milligrams per cubic metre on a dry basis, normalized to 11% oxygen at a reference temperature of 25 degrees Celsius and a reference pressure of 101.3 kilopascals, the Company shall perform a second Source Testing in accordance with the procedure outlined in Schedule "A", to determine the rate of emissions of the Test Contaminants listed in the Schedule "B" from the Targeted Sources.

4. CONTINUOUS MONITORING

1. The Company shall, prior to the commencement of operation of the Equipment, install and subsequently conduct and maintain a program to continuously monitor:
 - a. the carbon monoxide and oxygen concentration in the undiluted flue gas leaving the secondary chambers of the Equipment;
 - b. the temperature at the location in the each secondary chamber of the Equipment where the minimum retention time of the combustion gases at a minimum temperature of 1,000 degrees Celsius for at least one second is achieved.

The CEM System shall be equipped with continuous recording devices and shall comply with the requirements outlined in the attached Schedules "C", "D", and "E".

5. RECORD RETENTION

1. The Company shall retain, for a minimum of two (2) years from the date of their creation, all records and information related to or resulting from the recording activities required by this Approval. These records shall be made available to staff of the Ministry upon request. The Company shall retain:
 - a. all records on maintenance, repair and inspection of the Equipment and the CEM System;

- b. all records produced by the CEM System;
- c. all records of operator training;
- d. all records on the environmental complaints, including:
 - i. a description, time and date of the incident;
 - ii. wind direction at the time of the incident; and
 - iii. a description of the measures taken to address the cause of the incident and to prevent a similar occurrence in the future;
- e. daily records of each load processed by the Equipment
- f. description of any upset conditions associated with the operation of the Equipment and remedial action taken.

6. NOTIFICATION

1. The Company shall notify the District Manager, in writing, of each environmental complaint and the measures taken to address the complaint within two (2) business days of the complaint. The notification shall include:
 - a. a description of the nature of the complaint; and
 - b. the time and date of the incident to which the complaint relates.

7. NOISE

1. The Company shall, at all times, ensure that the noise emissions from the Facility comply with the limits set out in Ministry Publication NPC-300

SCHEDULE "A"

SOURCE TESTING PROCEDURES

1. The Company shall submit, not later than three (3) months after commencement of operation of the Equipment, to the Manager a Pre-Test Plan for the Source Testing required under this Approval, and, should a second Source Testing be required, the Company shall submit, not later than three (3) months after the completion of the first Source Testing, to the Manager a Pre-Test Plan for the Source Testing required under this Approval.
2. The Company shall finalize the test protocol in consultation with the Manager.
3. The Company shall not commence the Source Testing until the Manager has accepted the test protocol.
4. The Company shall complete the Source Testing not later than three (3) months after the Manager has accepted the test protocol.
5. The Company shall notify the District Manager and the Manager in writing of the location, date and time of any impending Source Testing required by this Approval, at least fifteen (15) days prior to the Source Testing.
6. The Company shall submit a report on the Source Testing to the District Manager and the Manager not later than two (2) months after completing the Source Testing. The report shall be in the format described in the Source Testing Code, and shall also include, but not be limited to:
 - a. an executive summary;
 - b. records of operating conditions at the time of Source Testing, including but not limited to the following:
 - i. all records produced by the continuous monitoring systems;
 - ii. production data;
 - iii. Facility/process information related to the operation of the Targeted Sources;
 - iv. description of the emission sources controlled by the Targeted Sources at the time of testing;
 - c. emission factor of the Test Contaminants from the Targeted Sources and the tabular comparison of Source Testing results from the Targeted Sources and Test Contaminants to the original emission estimates described in the Company's application and the ESDM Report.
7. The Director may not accept the results of the Source Testing if:

- a. the Source Testing Code or the requirements of the Manager were not followed; or
 - b. the Company did not notify the District Manager and the Manager of the Source Testing; or
 - c. the Company failed to provide a complete report on the Source Testing.
8. If the Director does not accept the results of the Source Testing, the Director may require re-testing. If re-testing is required, the Pre-Test Plan strategies need to be revised and submitted to the Manager for approval. The action taken to minimize the possibility of the Source Testing results not being accepted by the Director must be noted in the revision.
9. If the Source Testing results are higher than the emission estimates in the Company's ESDM Report, the Company shall update their ESDM Report in accordance with section 26 of O. Reg. 419/05 with the results from the Source Testing report and make these records available for review by staff of the Ministry upon request. The updated Emission Summary Table from the updated ESDM Report shall be submitted with the report on the Source Testing.

SCHEDULE "B"

Test Contaminants

- Total Hydrocarbon Compounds
- Hydrogen Chloride
- Total Suspended Particulate Matter
- Benzo(a) Pyrene
- Naphthalene
- Acrolein

List of Dioxins, Furans and Dioxin-like PCBs

- 2,3,7,8-Tetrachlorodibenzo-p-dioxin [2,3,7,8-TCDD]
- 1,2,3,7,8-Pentachlorodibenzo-p-dioxin [1,2,3,7,8-PeCDD]
- 1,2,3,4,7,8-Hexachlorodibenzo-p-dioxin [1,2,3,4,7,8-HxCDD]
- 1,2,3,6,7,8-Hexachlorodibenzo-p-dioxin [1,2,3,6,7,8-HxCDD]
- 1,2,3,7,8,9-Hexachlorodibenzo-p-dioxin [1,2,3,7,8,9-HxCDD]
- 1,2,3,4,6,7,8-Heptachlorodibenzo-p-dioxin [1,2,3,4,6,7,8-HpCDD]
- 1,2,3,4,6,7,8,9-Octachlorodibenzo-p-dioxin [1,2,3,4,6,7,8,9-OCDD]
- 2,3,7,8-Tetrachlorodibenzofuran [2,3,7,8-TCDF]
- 2,3,4,7,8-Pentachlorodibenzofuran [2,3,4,7,8-PeCDF]
- 1,2,3,7,8-Pentachlorodibenzofuran [1,2,3,7,8-PeCDF]
- 1,2,3,4,7,8-Hexachlorodibenzofuran [1,2,3,4,7,8-HxCDF]
- 1,2,3,6,7,8-Hexachlorodibenzofuran [1,2,3,6,7,8-HxCDF]
- 1,2,3,7,8,9-Hexachlorodibenzofuran [1,2,3,7,8,9-HxCDF]
- 2,3,4,6,7,8-Hexachlorodibenzofuran [2,3,4,6,7,8-HxCDF]
- 1,2,3,4,6,7,8-Heptachlorodibenzofuran [1,2,3,4,6,7,8-HpCDF]
- 1,2,3,4,7,8,9-Heptachlorodibenzofuran [1,2,3,4,7,8,9-HpCDF]
- 1,2,3,4,6,7,8,9-Octachlorodibenzofuran [1,2,3,4,6,7,8,9-OCDF]
- 3,3',4,4'-Tetrachlorobiphenyl [3,3',4,4'-tetraCB (PCB 77)]
- 3,4,4',5- Tetrachlorobiphenyl [3,4,4',5-tetraCB (PCB 81)]
- 3,3',4,4',5- Pentachlorobiphenyl (PCB 126) [3,3',4,4',5-pentaCB (PCB 126)]
- 3,3',4,4',5,5'- Hexachlorobiphenyl [3,3',4,4',5,5'-hexaCB (PCB 169)]
- 2,3,3',4,4'- Pentachlorobiphenyl [2,3,3',4,4'-pentaCB (PCB 105)]
- 2,3,4,4',5- Pentachlorobiphenyl [2,3,4,4',5-pentaCB (PCB 114)]
- 2,3',4,4',5- Pentachlorobiphenyl [2,3',4,4',5-pentaCB (PCB 118)]
- 2',3,4,4',5- Pentachlorobiphenyl [2',3,4,4',5-pentaCB (PCB 123)]
- 2,3,3',4,4',5- Hexachlorobiphenyl [2,3,3',4,4',5-hexaCB (PCB 156)]
- 2,3,3',4,4',5'- Hexachlorobiphenyl [2,3,3',4,4',5'-hexaCB (PCB 157)]
- 2,3',4,4',5,5'- Hexachlorobiphenyl [2,3',4,4',5,5'-hexaCB (PCB 167)]
- 2,3,3',4,4',5,5'- Heptachlorobiphenyl [2,3,3',4,4',5,5'-heptaCB (PCB 189)]

SCHEDULE "C"

Continuous Temperature Monitoring System

PARAMETER:

Temperature

LOCATION:

The sample point for the continuous temperature monitoring and recording system shall be installed in accordance with the requirements of Report EPS 1/PG/7 at a location where the measurements are representative of the minimum temperature of the undiluted gases according to the Condition 4.1.b.

PERFORMANCE:

The Continuous Temperature Monitor shall meet the following minimum performance specifications for the following parameters:

PARAMETERS	SPECIFICATION
Type	shielded "K" type thermocouple, or equivalent
Accuracy	± 1.5 percent of the minimum gas temperature
Response Time (95%)	60 sec. (max)
Operating Range (Full Scale)	1.5 times approval limit
Standard Tolerance	± 2.2 °C or ± 0.75%
Resolution	0.1 °C
Calibration	Per manufacturer's recommendations

RECORDER:

The recorder must be capable of registering continuously the measurement of the monitoring system without a significant loss of accuracy and with a time resolution of 5 minutes or better.

RELIABILITY:

The monitor shall be operated and maintained so that accurate data is obtained during a minimum of 90 percent of the time for each calendar quarter during the first full year of operation, and 95 percent, thereafter.

SCHEDULE "D"

Continuous Oxygen Monitoring System

PARAMETER:

Oxygen

INSTALLATION:

PARAMETERS	SPECIFICATION
Range (percentage)	0 to 20 or 0 to 25
Calibration Gas Ports	close to the sample point

PERFORMANCE:

The Continuous Oxygen Monitor shall meet the following minimum performance specifications for the following parameters.

PARAMETERS	SPECIFICATION
Span Value (percentage)	40% to 75% of Full Scale
Relative Accuracy	\leq the greater of 10 percent of the mean value of the reference method test data or 0.5% average absolute difference
Calibration Error	0.25 percent O ₂
System Bias	\leq the greater of 5 percent of the Full Scale value or 0.5% average absolute difference
Procedure for Zero and Span Calibration check	all system components checked
Zero Calibration Drift (24-hour)	\leq 0.5 percent O ₂
Span Calibration Drift (24-hour)	\leq 0.5 percent O ₂
Response Time (90 percent response to a step change)	\leq 200 seconds
Operational Test Period	\geq 168 hours without corrective maintenance

CALIBRATION:

Daily calibration drift checks on the monitor shall be performed and recorded in accordance with the requirements of Report EPS 1/PG/7.

DATA RECORDER:

The data recorder must be capable of registering continuously the measurement of the monitor with an accuracy of 0.5 percent of a full scale reading or better and with a time resolution of 2 minutes or better.

RELIABILITY:

The monitor shall be operated and maintained so that accurate data is obtained during a minimum of 90 percent of the time for each calendar quarter during the first full year of operation, and 95 percent, thereafter.

SCHEDULE "E"

Continuous Carbon Monoxide Monitoring System

PARAMETER:

Carbon Monoxide

INSTALLATION:

The Continuous Oxygen Monitor shall be installed in accordance with the requirements of Report EPS 1/PG/7 at an accessible location where the measurements are representative of the actual concentration of carbon monoxide in the undiluted gases leaving the secondary chamber of the Equipment and shall meet the following installation specifications.

PARAMETERS	SPECIFICATION
Range (parts per million, ppm)	0 to 100 (Low) and 0 to 2,000 (High)
Calibration Gas Ports	close to the sample point

PERFORMANCE:

The Continuous Carbon Monoxide Monitor shall meet the following minimum performance specifications for the following parameters:

PARAMETERS	SPECIFICATION
Span Value (nearest ppm equivalent)	40% to 75% of Full Scale
Relative Accuracy	\leq the greater of 10 percent of the mean value of the reference method test data or 8 ppm average absolute difference
Calibration Error	\leq 2 percent of actual concentration
System Bias	\leq the greater of 5 percent of the FS value or 5 ppm average absolute difference
Procedure for Zero and Span Calibration Check	all system components checked
Zero Calibration Drift (24-hour)	\leq 2.5 percent of FS or 2.5 ppm absolute difference
Span Calibration Drift (24-hour)	\leq 2.5 percent of FS or 2.5 ppm absolute difference
Response Time (90 percent response to a step change)	\leq 200 seconds

Operational Test Period	≥ 168 hours without corrective maintenance
-------------------------	--

CALIBRATION:

Daily calibration drift checks on the monitor shall be performed and recorded in accordance with the requirements of Report EPS 1/PG/7.

DATA RECORDER:

The data recorder must be capable of registering continuously the measurement of the monitor with an accuracy of 0.5 percent of a full scale reading or better and with a time resolution of 2 minutes or better.

RELIABILITY:

The monitor shall be operated and maintained so that accurate data is obtained during a minimum of 90 percent of the time for each calendar quarter during the first full year of operation, and 95 percent, thereafter.

The reasons for the imposition of these terms and conditions are as follows:

1. Condition No. 1 is included to provide minimum performance requirements considered necessary to prevent an adverse effect resulting from the operation of the Equipment.
2. Condition No. 2 is included to emphasize that the Equipment must be maintained and operated according to a procedure that will result in compliance with the EPA, the regulations and this Approval.
3. Condition Nos. 3 and 4 are included to require the Company to gather accurate information so that compliance with the operating requirements of this Approval can be verified.
4. Condition Nos 5 and 6 are included to require the Company to keep records and provide information to the Ministry so that the environmental impact and subsequent compliance with the EPA, the regulations and this Approval can verified.
5. Condition No. 7.1 is included to provide the minimum performance requirement considered necessary to prevent an adverse effect resulting from the operation of the Facility.
6. Condition No. 7.2 is included to ensure that the operation of the Equipment is not extended beyond the specified hours to prevent an adverse effect resulting from the operation of the Equipment.

In accordance with Section 139 of the Environmental Protection Act, you may by written Notice served upon me, the Environmental Review Tribunal and in accordance with Section 47 of the Environmental Bill of Rights, 1993, the Minister of the Environment, Conservation and Parks, within 15 days after receipt of this Notice, require a hearing by the Tribunal. The Minister of the Environment, Conservation and Parks will place notice of your appeal on the Environmental Registry. Section 142 of the Environmental Protection Act provides that the Notice requiring the hearing shall state:

- a. The portions of the environmental compliance approval or each term or condition in the environmental compliance approval in respect of which the hearing is required, and;
- b. The grounds on which you intend to rely at the hearing in relation to each portion appealed.

The Notice should also include:

1. The name of the appellant;
2. The address of the appellant;
3. The environmental compliance approval number;
4. The date of the environmental compliance approval;
5. The name of the Director, and;
6. The municipality or municipalities within which the project is to be engaged in.

And the Notice should be signed and dated by the appellant.

This Notice must be served upon:

The Secretary*
Environmental Review Tribunal
655 Bay Street, Suite 1500
Toronto, Ontario
M5G 1E5

AND

The Minister of the Environment,
Conservation and Parks
777 Bay Street, 5th Floor
Toronto, Ontario
M7A 2J3

AND

The Director appointed for the purposes of
Part II.1 of the Environmental Protection Act
Ministry of the Environment,
Conservation and Parks
135 St. Clair Avenue West, 1st Floor
Toronto, Ontario
M4V 1P5

*** Further information on the Environmental Review Tribunal's requirements for an appeal can be obtained directly from the Tribunal at: Tel: (416) 212-6349, Fax: (416) 326-5370 or www.ert.gov.on.ca**

This instrument is subject to Section 38 of the Environmental Bill of Rights, 1993, that allows residents of Ontario to seek leave to appeal the decision on this instrument. Residents of Ontario may seek leave to appeal within 15 days from the date this decision is placed on the Environmental Registry. By accessing the Environmental Registry at <https://ero.ontario.ca/>, you can determine when the leave to appeal period ends.

The above noted activity is approved under s.20.3 of Part II.1 of the Environmental Protection Act.

DATED AT TORONTO this 10th day of September, 2021



Neryed Ragbar, P.Eng.
Director
appointed for the purposes of Part II.1 of the
Environmental Protection Act

JK/

c: District Manager, MECP Halton-Peel
Bryce Dawson, RWDI Air Inc.