

**ENVIRONMENTAL COMPLIANCE APPROVAL**

NUMBER 8637-DL6J3S

Issue Date: January 12, 2026

North Glengarry BESS Inc.  
192 Spadina Ave, No. 506  
Toronto, Ontario  
M5T 2C2

Site Location: 1454 Skye Road  
Lots 28-29, Concession 9  
North Glengarry Township, United Counties of Stormont,  
Dundas and Glengarry  
K0B 2B0

*You have applied under section 20.2 of Part II.1 of the Environmental Protection Act, R.S.O. 1990, c. E. 19 (Environmental Protection Act) for approval of:*

establishment of sewage works for the collection, transmission and disposal of stormwater as well as spill containment works servicing a proposed battery energy storage system (BESS) site, on approximately 6.06 hectares of land located at the above Site address, consisting of the following proposed Works:

**Spill Containment Works**

complete with three (3) transformers containing approximately 3,335 litres of insulating mineral oil each; with the containment area designed to contain runoff from the 100-year storm event and any oil spill from the on-site transformers comprised of:

- three (3) spill containment pits located to the north-west of three battery pack installations, with each pit having an approximate length of 9 metres, width of 6.45 metres and depth of 0.85 metres excluding surface stone depth, each spill containment pit containing one (1) transformer with approximately 3,335 litres of insulating mineral oil each, with each containment pit providing a minimum spill containment volume of approximately 11,409 litres designed to contain runoff from a 100-year 24 hours storm event as well as 110% of the transformer oil volume of a single transformer;
- three (3) secondary oil containment systems installed within the three (3) containment pits (Sorbweb Plus with SAM), each consisting of 50 millimetre base sand layer, complete with impermeable liner on walls and around the transformer pad, one (1) oil mat and absorbent SAM layer covered by 50 millimetre sand layer and non-woven and woven geotextile layers below an approximate 0.75 metre

layer of fire quenching stone covered by a 0.15 metre layer of surface stone;

- three (3) 150 millimetre wick drain systems constructed below the secondary containment systems, discharging to the sump pit described below via 100 millimetre solid outlet pipe;
- one (1) stainless steel sump pit with an approximate length of 1.2 metres, width of 1.2 metres and depth of 2.0 metres, complete with a sump pump controlled via an oil monitoring device and discharging to a 100 millimetre diameter PVC storm sewer that will outlet at the south perimeter swale.

### **Stormwater Management Works**

- **Surface and Subsurface Storage (catchment area 0.4876 hectares):** providing a storage volume of approximately 140.1 cubic metres within the station's drainage stone, subdrain network and surface swales;
- **Subdrain System:** 150 millimetre diameter subdrain piping complete with clear stone layer wrapped in filter cloth and cleanouts, discharging via one (1) subdrain outlet to the perimeter swales described below;
- **Perimeter Swales:** flat bottom and v-shaped grassed swales along the perimeter of the site, with 3:1 side slopes and depths ranging from 0.15 to 0.67 metres, with the perimeter swales discharging to the farm field to the south-west, complete with rock flow check dams and rip-rap lined inlets and outlets;

including erosion/sedimentation control measures during construction and all other controls and appurtenances essential for the proper operation of the aforementioned Works;

all in accordance with the submitted application and supporting documents listed in Schedule A forming part of this Approval.

*For the purpose of this environmental compliance approval, the following definitions apply:*

1. "Approval" means this entire Environmental Compliance Approval and any Schedules attached to it;
2. "Director" means a person appointed by the Minister pursuant to section 5 of the EPA for the purposes of Part II.1 of the EPA;
3. "District Manager" means the District Manager of the appropriate local District Office of the Ministry, where the Works are geographically located;
4. "EPA" means the *Environmental Protection Act*, R.S.O. 1990, c.E.19, as amended;
5. "Licensed Engineering Practitioner" means a person who holds a licence, limited licence or temporary licence under the *Professional Engineers Act*, R.S.O. 1990, c. P.28;
6. "Ministry" means the ministry of the government of Ontario responsible for the EPA and

OWRA and includes all officials, employees or other persons acting on its behalf;

7. "Owner" means North Glengarry BESS Inc. and its successors and assignees;
8. "OWRA" means the *Ontario Water Resources Act* , R.S.O. 1990, c. O.40, as amended;
9. "Proposed Works" means those portions of the Works included in the Approval that are under construction or to be constructed;
10. "Works" means the approved sewage works, and includes Proposed Works.

*You are hereby notified that this environmental compliance approval is issued to you subject to the terms and conditions outlined below:*

## TERMS AND CONDITIONS

### 1. GENERAL PROVISIONS

1. The Owner shall ensure that any person authorized to carry out work on or operate any aspect of the Works is notified of this Approval and the terms and conditions herein and shall take all reasonable measures to ensure any such person complies with the same.
2. The Owner shall design, construct, operate and maintain the Works in accordance with the conditions of this Approval.
3. Where there is a conflict between a provision of any document referred to in this Approval and the conditions of this Approval, the conditions in this Approval shall take precedence.
4. The issuance of, and compliance with the conditions of, this Approval does not:
  - a. relieve any person of any obligation to comply with any provision of any applicable statute, regulation or other legal requirement, including, but not limited to, the obligation to obtain approval from the local conservation authority necessary to construct or operate the Works; or
  - b. limit in any way the authority of the Ministry to require certain steps be taken to require the Owner to furnish any further information related to compliance with this Approval.

## **2. EXPIRY OF APPROVAL**

1. This Approval will cease to apply to those parts of the Works which have not been constructed within **five (5) years** of the date of this Approval.
2. In the event that completion and commissioning of any portion of the Works is anticipated to be more than five (5) years, the Owner shall submit an application for extension at least **twelve (12) months** prior to the end of the five (5) years from the day of issuance of this Approval. The application shall include the reason(s) for the delay, whether there is any design change(s) and a review of whether the standards applicable at the time of Approval of the Works are still applicable at the time of request for extension, to ensure the ongoing protection of the environment.

## **3. CHANGE OF OWNER**

1. The Owner shall notify the District Manager and the Director, in writing, of any of the following changes within **thirty (30) days** of the change occurring:
  - a. change of address of Owner;
  - b. change of Owner, including address of new owner;
  - c. change of partners where the Owner is or at any time becomes a partnership, and a copy of the most recent declaration filed under the *Business Names Act, R.S.O. 1990, c. B.17* shall be included in the notification; or
  - d. change of name of the corporation, and a copy of the most current information filed under the *Corporations Information Act, R.S.O. 1990, c. C39* shall be included in the notification.
2. In the event of any change in ownership of the Works, the Owner shall notify in writing the succeeding owner of the existence of this Approval, and a copy of such notice shall be forwarded to the District Manager and the Director.
3. The Owner shall ensure that all communications made pursuant to this condition refer to the number of this Approval.

#### **4. CONSTRUCTION OF PROPOSED WORKS**

1. Upon the construction of the Works, the Owner shall prepare a statement, certified by a Licensed Engineering Practitioner, that the Works are constructed in accordance with this Approval, and upon request, shall make the written statement available for inspection by Ministry personnel.
2. Within **one (1) year** of the construction of the Proposed Works, a set of as-built drawings showing the Works “as constructed” shall be prepared. These drawings shall be kept up to date through revisions undertaken from time to time and a copy shall be retained at the Works for the operational life of the Works.

#### **5. OPERATION AND MAINTENANCE OF THE STORMWATER MANAGEMENT WORKS**

1. The Owner shall make all necessary investigations, take all necessary steps and obtain all necessary approvals so as to ensure that the physical structure, siting and operations of the Stormwater Management Works do not constitute a safety, health or flooding hazard to the general public.
2. The Owner shall undertake an inspection of the condition of the Stormwater Management Works, at least once a year, and undertake any necessary cleaning and maintenance to ensure that sediment, debris and excessive decaying vegetation are removed from the Stormwater Management Works to prevent the excessive build-up of sediment, oil/grit, debris and/or decaying vegetation, to avoid reduction of the capacity and/or permeability of the Stormwater Management Works, as applicable. The Owner shall also regularly inspect and clean out the inlet to and outlet from the Stormwater Management Works to ensure that these are not obstructed.
3. The Owner shall construct, operate and maintain the Stormwater Management Works with the objective that the effluent from the Stormwater Management Works is essentially free of floating and settleable solids and does not contain oil or any other substance in amounts sufficient to create a visible film, sheen, foam or discoloration on the receiving waters.
4. The Owner shall ensure the immediate clean-out of the Stormwater Management Works after a fuel or oil spill capture.
5. The Owner shall ensure that equipment and material for the containment, clean-up and disposal of fuel and oil and materials contaminated with such, is on hand and in good repair for immediate use in the event of:
  - a. loss of fuel or oil to the Stormwater Management Works; or
  - b. a spill within the meaning of Part X of the EPA.
6. The Owner shall prepare an operations manual prior to the commencement of operation of the Stormwater Management Works that includes, but is not necessarily limited to, the following information:

- a. operating and maintenance procedures for routine operation of the Stormwater Management Works;
- b. inspection programs, including frequency of inspection, for the Stormwater Management Works and the methods or tests employed to detect when maintenance is necessary;
- c. repair and maintenance programs, including the frequency of repair and maintenance for the Stormwater Management Works;
- d. contingency plans and procedures for dealing with potential abnormal situations and for notifying the District Manager, including a contingency plan in case water needs to be removed from the swale along with a monitoring plan for the water and/or for chemicals used in fire suppression or for materials consumed by the fire; and
- e. procedures for receiving, responding and recording public complaints, including recording any follow-up actions taken.

7. The Owner shall maintain an up to date operations manual and make the manual readily accessible for reference at the Stormwater Management Works for the operational life of the Stormwater Management Works. Upon request, the Owner shall make the manual available to Ministry staff.

8. The Owner shall maintain a logbook to record the results of these inspections and any cleaning and maintenance operations undertaken, and shall keep the logbook at the Stormwater Management Works for inspection by the Ministry. The logbook shall include the following:

- a. the name of the Stormwater Management Works;
- b. the date and results of each inspection, maintenance and cleaning, including an estimate of the quantity of any materials removed and method of clean-out of the Stormwater Management Works; and
- c. the date of each spill within the catchment area, including follow-up actions and remedial measures undertaken.

9. The Owner shall retain for a minimum of five (5) years from the date of their creation, all records and information related to or resulting from the operation and maintenance activities required by this Approval.

## **6. OPERATION AND MAINTENANCE OF THE SPILL CONTAINMENT WORKS**

1. The Owner shall ensure that the Spill Containment Works and related equipment and appurtenances which are installed or used to achieve compliance with this Approval are properly operated and maintained. The Owner shall check the Spill Containment Works on a monthly basis, as a minimum, and keep a record of the inspections in a log-book at the Station or alternatively in electronic format accessible to ministry staff upon request. Upon the request of

the Owner, the District Manager may reduce the frequency of inspection, in writing.

2. The Owner shall use best efforts to immediately identify and clean up all losses of oil from the transformers.
3. The Owner shall, upon identification of a loss of oil, take immediate action to prevent the further occurrence of such loss.
4. The Owner shall develop a contingency plan for groundwater monitoring in the event of a major spill or fire, to address the risk for potential contamination of the supply wells downgradient of the site, including the development of a comprehensive emergency response plan detailing procedures for addressing groundwater contamination incidents or complaints, identifying and preparing alternative water supply options including temporary trucked water supply or the installation of new supply wells for affected users in the event of proven contamination.
5. In furtherance of, but without limiting the generality of, the obligation imposed by Subsection (1), the Owner shall ensure that equipment and material for the containment, clean up and disposal of oil and materials contaminated with oil are kept on hand and in good repair for immediate use in the event of:
  - a. loss of oil from the transformers and equipment;
  - b. a spill within the meaning of Part X of the EPA; or
  - c. the identification of an abnormal amount of oil in the spill containment areas and/or in the sump pit.
6. The Owner shall ensure that the oil that is used in all transformers is free from Polychlorinated Biphenyls.

## **7. OPERATIONS MANUAL - SPILL CONTAINMENT WORKS**

1. In furtherance of, but without limiting the generality of the obligation imposed by Condition 6, the Owner shall prepare an operations manual prior to the commencement of operation of the Spill Containment Works.
2. The Owner shall ensure that the manual includes, but is not necessarily limited to, the following information:
  - a. operating procedures for routine operation of the Spill Containment Works and for periodic self-monitoring of the sump pit effluent;
  - b. inspection programs, including frequency of inspection, for the Spill Containment Works and the methods or tests employed to detect when maintenance is necessary;
  - c. repair and maintenance programs, including the frequency of repair and maintenance for

the Spill Containment Works;

- d. a spill prevention, control and countermeasures plan to address loss of oil from the transformers and oil discharge offsite, including procedures for notifying the District Manager; and
- e. procedures for receiving, responding and recording public complaints, including recording any follow-up actions taken.

3. The Owner shall maintain an up to date operations manual and make the manual readily accessible for reference at the Spill Containment Works for the operational life of the Spill Containment Works. Upon request, the Owner shall make the manual available to Ministry staff.

## **8. TEMPORARY EROSION AND SEDIMENT CONTROL**

1. The Owner shall install and maintain temporary sediment and erosion control measures during construction and conduct inspections once every two (2) weeks and after each significant storm event (a significant storm event is defined as a minimum of 25 millimetres of rain in any 24 hours period). The inspections and maintenance of the temporary sediment and erosion control measures shall continue until they are no longer required and at which time they shall be removed and all disturbed areas reinstated properly.
2. The Owner shall maintain records of inspections and maintenance which shall be made available for inspection by the Ministry, upon request. The record shall include the name of the inspector, date of inspection, and the remedial measures, if any, undertaken to maintain the temporary sediment and erosion control measures.

## **9. EFFLUENT OBJECTIVES - SPILL CONTAINMENT WORKS**

1. The Owner shall use best efforts to design, construct and operate the Spill Containment Works with the objective that the concentrations of the materials named as effluent parameters under the Effluent Objectives Table listed in Schedule B are not exceeded in the effluent from the Spill Containment Works.
2. In the event of an exceedance of one of the objectives set out in Subsection 1, the Owner shall:
  - a. notify the District Manager as soon as possible during normal working hours;
  - b. take immediate action to identify the source of contamination; and
  - c. take immediate action to prevent further exceedance.

## **10. EFFLUENT QUALITY MONITORING - SPILL CONTAINMENT WORKS**

1. The Owner is exempted from the requirement of a regular, Approval-imposed effluent

monitoring program for the effluent from the transformer Spill Containment Works under the following conditions:

- a. The Spill Containment Works shall be operated using Best Management Practices and in compliance with the established effluent objectives as set out in Condition 9, Subsection 1, as confirmed, from time to time, by recorded self-monitoring data;
- b. Ministry staff may enter the site of the Spill Containment Works at any reasonable time to inspect the Spill Containment Works which can include, but not be limited to, the taking of samples and copying of monitoring information from the station record; and
- c. The monitoring requirements as described under Subsection 2 below will be undertaken for twelve (12) months directly following a spill, with termination of the monitoring requirements to be determined by the District Manager at the end of the twelve (12) month period.

2. The Owner shall carry out the following effluent monitoring program immediately after a spill as defined under Condition 6, Subsection (4)(b):
  - a. The effluent from the spill affected containment area shall be sampled at the designated outlet, in accordance with the monitoring frequency and sample type specified for each parameter listed in the Effluent Monitoring Table included in Schedule B, unless otherwise required in writing by this Approval or by the District Manager.
  - b. In the event of an exceedance of the objective set out in Condition 9, Subsection 1, the Owner shall increase the frequency of sampling of the affected effluent from the containment area to once per month for each month that discharge occurs until it is demonstrated to the District Manager that the effluent complies with the said objective.
3. The methods and protocols for sampling, analysis, and recording shall conform, in order of precedence, to the methods and protocols specified in the following:
  - a. Ministry of the Environment publication "Protocol for the Sampling and Analysis of Industrial/Municipal Wastewater", January 2016, as amended from time to time by more recently published editions;
  - b. the publication "Standard Methods for the Examination of Water and Wastewater", 21st edition, 2005, as amended from time to time by more recently published editions.
4. The Owner shall retain for a minimum of five (5) years from the date of their creation, or longer if requested in writing by the District Manager, all records and information related to, or resulting from, the monitoring, inspection and maintenance activities required by this Approval.

## **11. REPORTING**

1. One (1) week prior to the start-up of the operation of the Works, the Owner shall notify the District Manager (in writing) of the pending start-up date.
2. The Owner shall, upon request, make all reports, manuals, plans, records, data, procedures and supporting documentation available to Ministry staff.
3. In addition to the obligations under Part X of the EPA and O. Reg. 675/98 (Classification and Exemption of Spills and Reporting of Discharges) made under the EPA, the Owner shall, within fifteen (15) days of the occurrence of any reportable spill as provided in Part X of the EPA and O. Reg. 675/98, submit a full written report of the occurrence to the District Manager describing the cause and discovery of the spill, clean-up and recovery measures taken, preventative measures to be taken and a schedule of implementation.
4. The Owner shall prepare performance reports on a calendar year basis and submit to the District Manager by March 31 upon request. The reports shall contain, but shall not be limited to, the following information pertaining to the reporting period:
  - a. a description of any operating problems encountered and corrective actions taken;
  - b. a summary of all maintenance carried out on any major structure, equipment, apparatus, mechanism or thing forming part of the Works, including an estimate of the quantity of any materials removed from the Works;
  - c. a summary of the calibration and maintenance carried out on all effluent monitoring equipment;
  - d. a summary of any effluent quality assurance or control measures undertaken in the reporting period;
  - e. a description of efforts made and results achieved in meeting the Effluent Objectives of Condition 5.9 and 9;
  - f. a summary of any complaints received during the reporting period and any steps taken to address the complaints;
  - g. a summary of all spill or abnormal discharge events; and
  - h. any other information the District Manager requires from time to time.

## **12. SPILL CONTINGENCY PLAN**

1. No later than four (4) weeks prior to commencement of operation of the Works, the Owner shall implement a spill contingency plan - that is a set of procedures describing how to mitigate the impacts of a spill within the area serviced by the Works. The Owner shall, upon request, make

this plan available to Ministry staff. This plan shall include as a minimum:

- a. the name, job title and location (address) of the Owner, person in charge, management or person(s) in control of the facility;
- b. the name, job title and 24-hour telephone number of the person(s) responsible for activating the spill contingency plan;
- c. a site plan drawn to scale showing the facility, nearby buildings, streets, catch-basins and manholes, drainage patterns (including direction(s) of flow in storm sewers), any receiving body(ies) of water that could potentially be significantly impacted by a spill and any features which need to be taken into account in terms of potential impacts on access and response (including physical obstructions and location of response and clean-up equipment);
- d. steps to be taken to report, contain, clean up and dispose of contaminants following a spill;
- e. a listing of telephone numbers for: local clean-up company(ies) who may be called upon to assist in responding to spills; local emergency responders including health institution(s); and Ministry Spills Action Centre 1-800-268-6060;
- f. Safety Data Sheets (SDS) for each hazardous material which may be transported or stored within the area serviced by the Works;
- g. the means (internal corporate procedures) by which the spill contingency plan is activated;
- h. a description of the spill response training provided to employees assigned to work in the area serviced by the Works, the date(s) on which the training was provided and by whom;
- i. an inventory of response and clean-up equipment available to implement the spill contingency plan, location and, date of maintenance/replacement if warranted; and
- j. the date on which the contingency plan was prepared and subsequently, amended.

2. The spill contingency plan shall be kept in a conspicuous, readily accessible location on-site.
3. The spill contingency plan shall be amended from time to time as required by changes in the operation of the facility.

*The reasons for the imposition of these terms and conditions are as follows:*

1. Condition 1 is imposed to ensure that the Works are constructed and operated in the manner in which they were described and upon which approval was granted. This condition is also included to emphasize the precedence of conditions in the Approval and the practice that the Approval is based on the most current document, if several conflicting documents are submitted for review. Condition 1.4 is included to emphasize that the issuance of this Approval does not diminish any other statutory and regulatory obligations to which the Owner is subject in the construction, maintenance and operation of the Works. The Condition specifically highlights the need to obtain any necessary conservation authority approvals. The Condition also emphasizes the fact that this Approval doesn't limit the authority of the Ministry to require further information.
2. Condition 2 is included to ensure that, when the Works are constructed, the Works will meet the standards that apply at the time of construction to ensure the ongoing protection of the environment.
3. Condition 3 is included to ensure that the Ministry records are kept accurate and current with respect to the approved Works and to ensure that subsequent owners of the Works are made aware of the Approval and continue to operate the Works in compliance with it.
4. Condition 4 is included to ensure that the Works are constructed in accordance with the approval and that record drawings of the Works "as constructed" are maintained for future references.
5. Condition 5 is included as regular inspection and necessary removal of sediment and excessive decaying vegetation from the Works are required to mitigate the impact of sediment, debris and/or decaying vegetation on the treatment capacity of the Works. The Condition also ensures that adequate storage is maintained in the Works at all times as required by the design. Furthermore, this Condition is included to ensure that the Works are operated and maintained to function as designed.
6. Condition 6 is included to ensure that the Works will be operated and maintained in a manner enabling compliance with the terms and conditions of this Approval, such that the environment is protected and deterioration, loss, injury or damage to any person or property is minimized and/or prevented.
7. Condition 7 is included to ensure that an operations manual governing all significant areas of operation, maintenance and repair is prepared, implemented and kept current by the Owner and made available to the Ministry, upon request. Such a manual is an integral part of the operation of the Works. Its compilation and use should assist the Owner in staff training and in identifying and planning for contingencies during possible abnormal conditions. The manual will also act as a bench-mark for Ministry staff when reviewing the Owner's

operation of the Works.

8. Condition 8 is included as installation, regular inspection and maintenance of the temporary sediment and erosion control measures is required to mitigate the impact on the downstream receiving watercourse during construction until they are no longer required.
9. Condition 9 is imposed to establish non-enforceable effluent quality objectives for the spill containment works which the Owner is obligated to use best efforts to meet on an ongoing basis. Also imposed are procedures to be followed to minimize environmental impact in the event the objectives are exceeded.
10. Condition 10 is related to sampling, monitoring and record keeping. They have been imposed to require the Owner to demonstrate, when required, that the performance of the Works is at a level consistent with the design and effluent objectives specified in the Approval and does not cause any impairment to the receiving watercourse, and that all pertinent information is available for any future review.
11. Condition 11 is included to provide a performance record for future references, to ensure that the Ministry is made aware of problems as they arise, and to provide a compliance record for all the terms and conditions outlined in this Approval, so that the Ministry can work with the Owner in resolving any problems in a timely manner.
12. Condition 12 is included to ensure that the Owner will implement the Spill Contingency Plan, such that the environment is protected and deterioration, loss, injury or damage to any person(s) or property is prevented

## **Schedule A**

1. Environmental Environmental Compliance Approval Application for Industrial Sewage Works submitted by HDR Corporation, dated July 14, 2025 and received on July 15, 2025, and all supporting documentation and information.
2. Stormwater Management Report "NORTH GLENGARRY BESS PROJECT, COMPASS ENERGY", dated April 2025, including calculations and engineering drawings, prepared by Parker Consulting Engineers LTD.

## Schedule B

### Effluent Objectives Table - Spill Containment Works

Effluent Parameter	Concentration Objective
Oil and Grease	15 mg/L
Phenol	20 µg/L
Polychlorinated Biphenyls (PCB)	0.05 ug/L

### Effluent Monitoring Table - Spill Containment Works

(measured at the discharge outlet from spill containment pit)

Frequency	Quarterly
Sample Type	Grab
Parameters	Oil and Grease, Polychlorinated Biphenyls (PCB), Phenol, PAHs, BTEX

In accordance with Section 139 of the *Environmental Protection Act*, you may by written notice served upon me, the Ontario Land Tribunal and in accordance with Section 47 of the *Environmental Bill of Rights*, 1993, the Minister of the Environment, Conservation and Parks, within 15 days after receipt of this notice, require a hearing by the Tribunal. The Minister of the Environment, Conservation and Parks will place notice of your appeal on the Environmental Registry. Section 142 of the *Environmental Protection Act* provides that the notice requiring the hearing ("the Notice") shall state:

- a. The portions of the environmental compliance approval or each term or condition in the environmental compliance approval in respect of which the hearing is required, and;
- b. The grounds on which you intend to rely at the hearing in relation to each portion appealed.

The Notice should also include:

1. The name of the appellant;
2. The address of the appellant;
3. The environmental compliance approval number;
4. The date of the environmental compliance approval;
5. The name of the Director, and;
6. The municipality or municipalities within which the project is to be engaged in.

And the Notice should be signed and dated by the appellant.

This Notice must be served upon:

Registrar\*  
Ontario Land Tribunal  
655 Bay Street, Suite 1500  
Toronto, Ontario  
M5G 1E5  
OLT.Registrar@ontario.ca

and

The Minister of the Environment,  
Conservation and Parks  
777 Bay Street, 5th Floor  
Toronto, Ontario  
M7A 2J3

and  
The Director appointed for the purposes of  
Part II.1 of the *Environmental Protection Act*  
Ministry of the Environment,  
Conservation and Parks  
135 St. Clair Avenue West, 1st Floor  
Toronto, Ontario  
M4V 1P5

\* **Further information on the Ontario Land Tribunal's requirements for an appeal can be obtained directly from the Tribunal at: Tel: (416) 212-6349 or 1 (866) 448-2248, or [www.olt.gov.on.ca](http://www.olt.gov.on.ca)**

This instrument is subject to Section 38 of the *Environmental Bill of Rights*, 1993, that allows residents of Ontario to seek leave to appeal the decision on this instrument. Residents of Ontario may seek leave to appeal within 15 days from the date this decision is placed on the Environmental Registry. By accessing the Environmental Registry at <https://ero.ontario.ca/>, you can determine when the leave to appeal period ends.

The above noted activity is approved under s.20.3 of Part II.1 of the *Environmental Protection Act*.

DATED AT TORONTO this 12th day of January, 2026



---

Neryed Ragbar, P.Eng.

Director

appointed for the purposes of Part II.1 of the  
*Environmental Protection Act*

YZ/

c: Area Manager, MECP Cornwall Area Office  
c: District Manager, MECP Ottawa District Office  
Janine Ralph, HDR Corporation