

ENVIRONMENTAL COMPLIANCE APPROVAL

NUMBER 4885-DSWSJ7
Issue Date: April 23, 2026

Tens on East Lake Realty Inc.
1 Greystone Court
Toronto, Ontario
M8V 4A5

Site Location: 41 Willow Lane
Prince Edward County

You have applied under section 20.2 of Part II.1 of the Environmental Protection Act, R.S.O. 1990, c. E. 19 (Environmental Protection Act) for approval of:

the establishment of Works for the treatment of sanitary sewage and subsurface disposal of treated effluent from a Sewage Treatment Plant (Newterra MBR Treatment System) at the above site location, rated at a Maximum Daily Flow of 19,311 litres per day with a balanced flow of 15,000 litres per day, consisting of the following:

Details of Service Area:

- **Type of Occupancy:** Commercial Tourist Facility
- **Type and Number of Units:**
 - six (6) single bedroom cabins, five (5) two-bedroom cabins, a 12-unit Motel, a clubhouse, an office building, and an existing barn.

Proposed Works

Newterra Membrane Bioreactor (MBR) Treatment System

one (1) in-ground FRP circular tank included with five (5) compartments described as follows:

Primary Treatment System

Primary Clarifier/Sludge Holding

- one (1) primary clarifier tank, having a working capacity of approximately 15 cubic metres and complete with an access riser with hatch and high level alarm instrumentation, receiving raw sewage from the proposed on-site facilities described above and waste activated sludge (WAS) from a membrane tank, and

discharging primary effluent to an equalization tank as described below;

Flow-Equalization

- one (1) flow equalization tank, having a working capacity of approximately 21.8 cubic metres, equipped with one (1) submersible sewage pump rated at 13.4 litres per minute and coarse bubble air diffusers receiving air supply from one (1) air mixing blower, and complete with an access riser with hatch and high/low level alarm instrumentation, discharging to a pre-anoxic tank as described below;

Secondary Treatment System

Pre-Anoxic

- one (1) pre-anoxic tank for denitrification, having a working capacity of approximately 7.3 cubic metres, equipped with one (1) submersible sewage pump and complete with an access riser with hatch and high level alarm instrumentation, receiving the equalization tank effluent and a recycle stream from an aerobic tank described below, discharging effluent to the aerobic tank;

Aerobic

- one (1) aerobic tank having a working capacity of approximately 12 cubic metres, equipped with fine bubble air diffusers receiving air supply from one (1) air mixing blowers rated at 70.5 normal cubic metres per hour, and one (1) submersible recirculation pump rated at 41.7 litres per minute discharging the mixed liquor back to the pre-anoxic tank described above, and complete with an access riser with hatch and instrumentation (high level alarm, pH transmitter and DO transmitter), discharging effluent by gravity to a post-anoxic tank as described below; and

Post-Anoxic

- one (1) post-anoxic tank for denitrification, having a working capacity of approximately 7.3 cubic metres, equipped with one (1) submersible sewage pump (for mixing) and one (1) submersible feed forward sewage pump, rated at 52.1 litres per minute, and complete with an access riser with hatch and high/low level alarm instrumentation, discharging effluent to membrane tank as described below;

Membrane Filtration

- one (1) membrane tank housed inside a modular enclosure, having a working capacity of approximately 2 cubic metres and equipped with two (2) submerged ultrafiltration membrane module (zeeweed) having a total membrane surface area of 56 square metres, one (1) air scouring blower rated at 15.8 normal cubic metres per hour, and one (1) permeate extraction pump rated at 23.1 litres per minute, complete with high level alarm instrumentation; discharging return activated sludge to the aerobic tank and Final Effluent to an effluent dosing tank as described below;

Supplementary Treatment System

- one (1) chemical dosing system consisting of one (1) Sodium Hydroxide dosing pump with spill containment and one (1) Aluminum Sulphate dosing pump with spill containment, dosing into the return streams from the membrane tanks to the aerobic tank.

Effluent Dosing Tank

- one (1) pre-cast concrete effluent dosing tank having a total capacity of approximately 4,500 litres (minimum), equipped with two (2) submersible effluent pumps, rated at approximately 5.4 litres per second at 3 metre total dynamic head, evenly dosing the proposed Type A dispersal bed as described below via a 75 millimetre diameter forcemain;

Influent Sampling Point

- sampling of Influent from the flow equalization tank.

Final Effluent Flow Measurement and Sampling Point

- one (1) flow measurement device on discharge pipe to the effluent dosing tank;
- sampling of Final Effluent at the effluent dosing tank.

Final Effluent Disposal Facilities ($Q_{MAX} = 15$ cubic metres per day)

- one (1) raised Type A dispersal bed, receiving effluent from the Effluent Dosing Tank, having a 300 millimetre thick stone layer comprised of 50 millimetre washed septic stone, with a total area of minimum 300 square metres, protected by permeable geo-textile fabric, complete with ten (10) runs of 24.5 metre long 100 millimetre diameter perforated distribution piping spaced approximately 1.2 metres apart, centre to centre in the stone layer, underlain by minimum of 1,875 square metres, 0.3 metres of imported sand with a percolation time (T) of 8-15 minutes per centimetre and 0.1 metres of topsoil/grass and 0.2 metres of sand above the stone layer.

Existing Works to be Decommissioned

- five (5) class 4 sewage systems each comprised of one (1) septic tank and one leaching bed.

all other controls, electrical equipment, instrumentation, piping, pumps, valves and appurtenances essential for the proper operation of the aforementioned Works;

all in accordance with the submitted supporting documents listed in **Schedule A**.

For the purpose of this environmental compliance approval, the following definitions apply:

1. "Approval" means this entire document and any schedules attached to it, and the application;
2. "BOD₅" (also known as TBOD₅) means five day biochemical oxygen demand measured in an unfiltered sample and includes carbonaceous and nitrogenous oxygen demand;
3. "CBOD₅" means five day carbonaceous (nitrification inhibited) biochemical oxygen demand measured in an unfiltered sample;

4. "Commissioned" means the construction is complete and the system has been tested, inspected, and is ready for operation consistent with the design intent;
5. "Director" means a person appointed by the Minister pursuant to Section 5 of the EPA for the purposes of Part II.I of the EPA;
6. "District Manager" means the District Manager of the appropriate local district office of the Ministry where the Works is geographically located;
7. "EPA" means the Environmental Protection Act, R.S.O. 1990, c.E.19, as amended;
8. "Existing Works" means those portions of the Works included in the Approval that have been constructed previously;
9. "Grab Sample" means an individual sample of at least 1000 millilitres collected in an appropriate container at a randomly selected time over a period of time not exceeding 15 minutes;
10. "Licensed Engineering Practitioner" means a person who holds a licence, limited licence or temporary licence under the *Professional Engineers Act*, R.S.O. 1990, c. P.28;
11. "Maximum Daily Flow" means the largest volume of flow to be received during a one-day period for which the Works is designed to handle;
12. "Ministry" means the ministry of the government of Ontario responsible for the EPA and OWRA and includes all officials, employees or other persons acting on its behalf;
13. "OBC" means the Ontario Building Code, Ontario Regulation 163/24 (Building Code) as amended to January 1, 2025, made under the *Building Code Act*, 1992, S.O. 1992, c. 23;
14. "Owner" means Tens on East Lake Realty Inc. and its successors and assignees;
15. "OWRA" means the *Ontario Water Resources Act*, R.S.O. 1990, c. O.40, as amended;
16. "Proposed Works" means those portions of the Works included in the Approval that are under construction or to be constructed;
17. "Works" means the approved sewage works, and includes Proposed Works and Existing Works.

You are hereby notified that this environmental compliance approval is issued to you subject to the terms and conditions outlined below:

TERMS AND CONDITIONS

1. GENERAL PROVISIONS

1. The Owner shall ensure that any person authorized to carry out work on or operate any aspect of the Works is notified of this Approval and the terms and conditions herein and shall take all reasonable measures to ensure any such person complies with the same.
2. The Owner shall design, construct, operate and maintain the Works in accordance with the conditions of this Approval.
3. Where there is a conflict between a provision of any document referred to in this Approval and the conditions of this Approval, the conditions in this Approval shall take precedence.

2. EXPIRY OF APPROVAL

1. This Approval will cease to apply to those parts of the Works which have not been constructed within **five (5) years** of the date of this Approval.
2. In the event that completion and commissioning of any portion of the Works is anticipated to be more than five (5) years, the Owner shall submit an application for extension at least **twelve (12) months** prior to the end of the five (5) years from the day of issuance of this Approval. The application shall include the reason(s) for the delay, whether there is any design change(s) and a review of whether the standards applicable at the time of Approval of the Works are still applicable at the time of request for extension, to ensure the ongoing protection of the environment.

3. CHANGE OF OWNER

1. The Owner shall notify the District Manager and the Director, in writing, of any of the following changes within **thirty (30) days** of the change occurring:
 - a. change of address of Owner;
 - b. change of Owner, including address of new owner;
 - c. change of partners where the Owner is or at any time becomes a partnership, and a copy of the most recent declaration filed under the *Business Names Act* , R.S.O. 1990, c.B17 shall be included in the notification;
 - d. change of name of the corporation and a copy of the most current information filed under the *Corporations Information Act* , R.S.O. 1990, c. C39 shall be included in the notification.
2. In the event of any change in ownership of the Works, other than a change to a successor municipality, the Owner shall notify in writing the succeeding owner of the existence of this Approval, and a copy of such notice shall be forwarded to the District Manager and the Director.
3. The Owner shall ensure that all communications made pursuant to this condition refer to the number

of this Approval.

4. CONSTRUCTION

1. The Owner shall ensure that the construction of the Works is supervised by a Licensed Engineering Practitioner.
2. The Owner shall ensure that the Works are constructed such that minimum horizontal clearance distances as specified in the OBC are satisfied.
3. The Owner shall ensure that the Newterra Membrane Bioreactor (MBR) treatment system is installed in accordance with the manufacturer's installation manual.
4. The Owner shall ensure that an imported soil that is required for construction of any subsurface disposal bed as per this Approval is tested and verified by a Licensed Engineering Practitioner for the percolation time (T) prior to delivering to the site location and the written records are kept at the site.
5. Within **six (6) months** of the Works being Commissioned, the Owner shall prepare a statement, certified by a Licensed Engineering Practitioner, that the Works are constructed in accordance with this Approval, and upon request, shall make the written statement available for inspection by Ministry staff.
6. Within **six (6) months** of the Works being Commissioned, the Owner shall prepare a set of as-built drawings showing the Works "as constructed". "As-built" drawings shall be kept up to date through revisions undertaken from time to time and a copy shall be retained at the site for the operational life of the Works and shall be made available for inspection by Ministry staff.

5. MONITORING AND RECORDING

The Owner shall, upon commencement of operation of the Works, carry out the following monitoring program:

1. All samples and measurements taken for the purpose of this Approval are to be taken at a time and in a location characteristic of the quality and quantity of the effluent stream over the time period being monitored.
2. Samples shall be collected at the sampling point(s), at the sampling frequencies and using the sample type specified for each parameter listed in the Influent Monitoring Table included in **Schedule B**.
3. Samples shall be collected at the sampling point(s), at the sampling frequencies and using the sample type specified for each parameter listed in the Effluent Monitoring Table included in **Schedule B**.
4. The Owner shall employ measurement devices to accurately measure quantity of effluent being discharged to each individual subsurface disposal bed, including but not limited to water/wastewater

flow meters, event counters, running time clocks, or electronically controlled dosing, and shall record the daily volume of effluent being discharged to the subsurface disposal bed.

5. The Owner shall ensure that the flow of treated effluent discharged into the subsurface disposal bed does not exceed 15,000 litres per day.
6. The methods and protocols for sampling, analysis and recording shall conform, in order of precedence, to the methods and protocols specified in the following documents and all analysis shall be conducted by a laboratory accredited to the ISO/IEC:17025 standard or as directed by the District Manager:
 - a. the Ministry's Procedure F-10-1, "Procedures for Sampling and Analysis Requirements for Municipal and Private Sewage Treatment Works (Liquid Waste Streams Only), as amended from time to time by more recently published editions;
 - b. the Ministry's publication "Protocol for the Sampling and Analysis of Industrial/Municipal Wastewater Version 2.0" (January 2016), PIBS 2724e02, as amended; and
 - c. the publication "Standard Methods for the Examination of Water and Wastewater" (21st edition), as amended from time to time by more recently published editions.
7. The Owner shall retain for a minimum of **five (5) years** from the date of their creation, all records and information related to or resulting from the monitoring activities required by this Approval.

6. EFFLUENT OBJECTIVES

1. The Owner shall design and undertake everything practicable to operate the Works in accordance with the Final Effluent parameters design objectives listed in the table(s) included in **Schedule B**.
2. For the purposes of subsection 1:
 - a. The concentrations of CBOD5 and TSS named in Column 1 of Effluent Objectives Table listed in **Schedule B**, as measured at each monitoring event, should be compared to the corresponding concentration set out in Column 2 of Effluent Objectives Table listed in **Schedule B**.
 - b. Seasonal Average Effluent concentrations of TP named in Column 1 of Effluent Objectives Table listed in **Schedule B**, should be compared to the corresponding concentration set out in Column 2 of Effluent Objectives Table listed in **Schedule B**.

7. EFFLUENT LIMITS

1. The Owner shall design, construct, operate and maintain the Works such that the concentrations of the materials named as effluent parameters in the Effluent Limits Table in **Schedule B** are not

exceeded in the effluent from the Works.

2. For the purposes of determining compliance with and enforcing subsection (1):
 - a. The Seasonal Average Effluent Concentration of CBOD₅, TSS and TP named in Column 1 of the Effluent Limits Table listed in **Schedule B** shall not exceed the corresponding maximum concentration set out in Column 2 of the Effluent Limits Table listed in **Schedule B**.

8. OPERATIONS AND MAINTENANCE

1. The Owner shall ensure that, at all times, the Works and the related equipment and appurtenances used to achieve compliance with this Approval are properly operated and maintained. Proper operation and maintenance shall include effective performance, adequate funding, adequate staffing and training, including training in all procedures and other requirements of this Approval and the OWRA and regulations, adequate laboratory facilities, process controls and alarms and the use of process chemicals and other substances used in the Works.
2. The Owner shall prepare an operations manual within **six (6) months** of the introduction of sewage to the Works, that includes, but not necessarily limited to, the following information:
 - a. operating procedures for routine operation of all the Works;
 - b. inspection programs, including frequency of inspection, for all the Works and the methods or tests employed to detect when maintenance is necessary;
 - c. repair and maintenance programs, including the frequency of repair and maintenance for all the Works; copies of maintenance contracts for any routine inspections and pump-outs should be included for all the tanks and treatment units;
 - d. procedures for the inspection and calibration of monitoring equipment;
 - e. a spill prevention control and countermeasures plan, consisting of contingency plans and procedures for dealing with equipment breakdowns, potential spills and any other abnormal situations, including notification of the Spills Action Centre (SAC) and District Manager; and
 - f. procedures for receiving, responding and recording public complaints, including recording any follow-up actions taken.
3. The Owner shall maintain an up to date operations manual and make the manual readily accessible for reference at the Works for the operational life of the Works. Upon request, the Owner shall make the manual available to Ministry staff.
4. The Owner shall, upon completion of construction, prepare and make available for inspection by Ministry staff, a maintenance agreement with the manufacturer for the treatment process/technology or its authorized agent. The maintenance agreement must be retained at the site and kept current for

the operational life of the Works.

5. The Owner shall ensure that all septic tanks are pumped out every 3-5 years or when the tank is 1/3 full of solids and the effluent filters are cleaned out at minimum once a year or more often if required.
6. The Owner shall ensure that grass-cutting is maintained regularly over the subsurface disposal bed(s), and that adequate steps are taken to ensure that the area of the underground Works is protected from vehicle traffic.
7. The Owner shall visually inspect the general area where Works are located for break-out once every month during the operating season.
8. In the event a break-out is observed from a subsurface disposal bed, the Owner shall do the following:
 - a. sewage discharge to that subsurface disposal system shall be discontinued;
 - b. the incident shall be **immediately** reported verbally to the Spills Action Centre (SAC) at (416) 325-3000 or 1-800-268-6060;
 - c. submit a written report to the District Manager within **one (1) week** of the break-out;
 - d. access to the break-out area shall be restricted until remedial actions are complete;
 - e. during the time remedial actions are taking place the sewage generated at the site shall not be allowed to discharge to the environment; and
 - f. sewage generated at the site shall be safely collected and disposed of through a licensed waste hauler to an approved sewage disposal site.
9. The Owner shall employ for the overall operation of the Works a person who possesses the level of training and experience sufficient to allow safe and environmentally sound operation of the Works.
10. The Owner shall retain for a minimum of **five (5) years** from the date of their creation, all records and information related to or resulting from the operations and maintenance activities required by this Approval.

9. REPORTING

1. **One week** prior to the start up of the operation of the Works, the Owner shall notify the District Manager (in writing) of the pending start up date.
2. The Owner shall report to the District Manager orally **as soon as possible** any non-compliance with the compliance limits specified in subsection 2 of **Condition 7**, and in writing within **seven (7) days**

of non-compliance.

3. In addition to the obligations under Part X of the EPA and O. Reg. 675/98 (Classification and Exemption of Spills and Reporting of Discharges) made under the EPA, the Owner shall, within **fifteen (15) days** of the occurrence of any reportable spill as provided in Part X of the EPA and O. Reg. 675/98, submit a full written report of the occurrence to the District Manager describing the cause and discovery of the spill, clean-up and recovery measures taken, preventative measures to be taken and a schedule of implementation.
4. The Owner shall, upon request, make all manuals, plans, records, data, procedures and supporting documentation available to Ministry staff.
5. The Owner shall prepare a performance report on an annual basis, and submit upon request to the District Manager in an electronic format by March 31 of the calendar year following the period being reported upon. The first such report shall cover the first annual period following the commencement of operation of the Works and subsequent reports shall cover successive annual periods following thereafter. The reports shall contain, but shall not be limited to, the following information:
 - a. a summary and description of efforts made and results achieved in meeting the effluent objectives of Condition 6;
 - b. a summary and interpretation of all monitoring data and a comparison to the effluent limits (Condition 7) including an overview of the success and adequacy of the Works, and a contingency plan in the event of non-compliance with the effluent limits.
 - c. a review and assessment of the performance of the Works, including all treatment units and subsurface disposal bed;
 - d. a description of any operating problems encountered and corrective actions taken for all Works located at the property;
 - e. a record of all maintenance carried out on any major structure, equipment, apparatus, mechanism or thing forming part of all Works located at the property including but not limited to: records of maintenance inspections for the treatment system, records of septic tank effluent filters cleaning, records of septic tank pump-outs, records of sludge pump-outs accumulated from the treatment system, records of visual inspections of all subsurface disposal systems;
 - f. a summary of any effluent quality assurance or control measures undertaken in the reporting period;
 - g. a summary and interpretation of all daily flow data and results achieved in not exceeding the Maximum Daily Flow / balanced flow discharged into each one of the subsurface disposal system;

- h. a summary of any complaints received during the reporting period and any steps taken to address the complaints;
- i. a summary of all spill or abnormal discharge events;
- j. any other information the District Manager requires from time to time;

10. DECOMMISSIONING OF UN-USED WORKS

1. The Owner shall properly abandon any portion of unused existing Works, as directed below, and upon completion of decommissioning, report in writing to the District Manager:
 - a. any sewage pipes leading from building structures to unused Works components shall be disconnected and capped;
 - b. any unused septic tanks, holding tanks and pump chambers shall be completely emptied of its content by a licensed hauler and either be removed, crushed and backfilled, or be filled with granular material;
 - c. if the area of the existing leaching bed is going to be used for the purposes of construction of a replacement bed or other structure, all distribution pipes and surrounding material must be removed by a licensed hauler and disposed off site at an approved waste disposal site; otherwise the existing leaching bed may be abandoned in place after disconnecting, if there are no other plans to use the area for other purposes.

The reasons for the imposition of these terms and conditions are as follows:

1. Condition 1 is imposed to ensure that the Works are built and operated in the manner in which they were described for review and upon which approval was granted. This condition is also included to emphasize the precedence of Conditions in the Approval and the practice that the Approval is based on the most current document, if several conflicting documents are submitted for review. The condition also advises the Owners their responsibility to notify any person they authorized to carry out work pursuant to this Approval the existence of this Approval.
2. Condition 2 is included to ensure that, when the Works are constructed, the Works will meet the standards that apply at the time of construction to ensure the ongoing protection of the environment.
3. Condition 3 is included to ensure that the Ministry records are kept accurate and current with respect to the approved Works and to ensure that subsequent owners of the Works are made aware of the Approval and continue to operate the Works in compliance with it.
4. Condition 4 is included to ensure that the Works are constructed, and may be operated and maintained such that the environment is protected and deterioration, loss, injury or damage to any person or property is

prevented.

5. Condition 5 is included to enable the Owner to evaluate and demonstrate the performance of the Works, on a continual basis, so that the Works are properly operated and maintained at a level which is consistent with the design objectives/limits specified in the Approval and that the Works does not cause any impairment to the groundwater and/or receiving watercourse.
6. Condition 6 is imposed to establish non-enforceable effluent quality objectives which the Owner is obligated to use best efforts to strive towards on an ongoing basis. These objectives are to be used as a mechanism to trigger corrective action proactively and voluntarily before environmental impairment occurs.
7. Condition 7 is imposed to ensure that the effluent discharged from the Works to the groundwater meets the Ministry's effluent quality requirements thus minimizing environmental impact on the groundwater and/or receiving watercourse.
8. Condition 8 is included to require that the Works be properly operated, maintained, and equipped such that the environment is protected. As well, the inclusion of an operations manual, maintenance agreement with the manufacturer for the treatment process/technology and a complete set of "as constructed" drawings governing all significant areas of operation, maintenance and repair is prepared, implemented and kept up-to-date by the owner and made available to the Ministry. Such information is an integral part of the operation of the Works. Its compilation and use should assist the Owner in staff training, in proper plant operation and in identifying and planning for contingencies during possible abnormal conditions. The manual will also act as a benchmark for Ministry staff when reviewing the Owner's operation of the Works.
9. Condition 9 is included to provide a performance record for future references, to ensure that the Ministry is made aware of problems as they arise, and to provide a compliance record for all the terms and conditions outlined in this Approval, so that the Ministry can work with the Owner in resolving any problems in a timely manner.
10. Condition 10 is included to ensure that any components of un-used Works are properly decommissioned.

Schedule A

1. Application for Environmental Compliance Approval submitted by Connor Padden, Director of Tens on East Lake Realty Inc. received on February 04, 2025 for the proposed Allswell Resort package treatment system and subsurface disposal bed, including design report, final plans and specifications.

Schedule B

Influent Monitoring Table

Sampling Location	Flow Equalization Tank
Frequency	Monthly during operating season
Sample Type	Grab
Parameters	BOD ₅ Total Suspended Solids (TSS) Total Kjeldahl Nitrogen (TKN) Total Phosphorus (TP)

Effluent Monitoring Table

Sampling Location	Effluent Dosing Tank
Frequency	Monthly during operating season
Sample Type	Grab
Parameters	CBOD ₅ Total Suspended Solids (TSS) Total Phosphorus (TP) Total Ammonia Nitrogen (TAN) Nitrate Nitrogen Nitrite Nitrogen

Effluent Objectives Table

Effluent Parameter (tested on outlet from Newterra Membrane Bioreactor (MBR) treatment system)	Concentration Objective (milligrams per litre unless otherwise indicated)
CBOD5	5
Total Suspended Solids	5
Total Phosphorous	0.1

Effluent Limits Table

Effluent Parameter (tested on outlet from the final Newterra Membrane Bioreactor (MBR) treatment system)	Concentration Limit (milligrams per litre unless otherwise indicated)
CBOD5	10
Total Suspended Solids (TSS)	10
TP	0.2

In accordance with Section 139 of the *Environmental Protection Act*, you may by written notice served upon me, the Ontario Land Tribunal and in accordance with Section 47 of the *Environmental Bill of Rights*, 1993, the Minister of the Environment, Conservation and Parks, within 15 days after receipt of this notice, require a hearing by the Tribunal. The Minister of the Environment, Conservation and Parks will place notice of your appeal on the Environmental Registry. Section 142 of the *Environmental Protection Act* provides that the notice requiring the hearing ("the Hearing") shall state:

- a. The portions of the environmental compliance approval or each term or condition in the environmental compliance approval in respect of which the hearing is required, and;
- b. The grounds on which you intend to rely at the hearing in relation to each portion appealed.

The Notice should also include:

1. The name of the appellant;
2. The address of the appellant;
3. The environmental compliance approval number;
4. The date of the environmental compliance approval;
5. The name of the Director, and;
6. The municipality or municipalities within which the project is to be engaged in.

And the Notice should be signed and dated by the appellant.

This Notice must be served upon:

Registrar*
Ontario Land Tribunal
655 Bay Street, Suite 1500
Toronto, Ontario
M5G 1E5
OLT.Registrar@ontario.ca

and

The Minister of the Environment,
Conservation and Parks
777 Bay Street, 5th Floor
Toronto, Ontario
M7A 2J3

and


The Director appointed for the purposes of
Part II.1 of the *Environmental Protection Act*
Ministry of the Environment,
Conservation and Parks
135 St. Clair Avenue West, 1st Floor
Toronto, Ontario
M4V 1P5

* **Further information on the Ontario Land Tribunal's requirements for an appeal can be obtained directly from the Tribunal at: Tel: (416) 212-6349 or 1 (866) 448-2248, or www.olt.gov.on.ca**

This instrument is subject to Section 38 of the *Environmental Bill of Rights*, 1993, that allows residents of Ontario to seek leave to appeal the decision on this instrument. Residents of Ontario may seek leave to appeal within 15 days from the date this decision is placed on the Environmental Registry. By accessing the Environmental Registry at <https://ero.ontario.ca/>, you can determine when the leave to appeal period ends.

The above noted activity is approved under s.20.3 of Part II.1 of the *Environmental Protection Act*.

DATED AT TORONTO this 23rd day of April, 2026



Fariha Pannu, P.Eng.

Director

appointed for the purposes of Part II.1 of the
Environmental Protection Act

SN/

c: Area Manager, MECP Belleville

c: District Manager, MECP Kingston - District
Martin Burger, Groundwork Engineering Limited