

**Ministry of the Environment,
Conservation and Parks**
Floor 1, 135 St Clair Ave W
Toronto, ON
M4V 1P5
Telephone: (416) 314-7998

**Ministère de l'Environnement, de la
Protection de la nature et des Parcs**
1er étage, 135 av St. Clair O
Toronto, ON
M4V 1P5
Téléphone : (416) 314-7998



September 18, 2025

Gurdev Dhijan, Owner
2757402 Ontario Inc.
58 Runnymede Cres
Brampton, Ontario
L6R 0L2

Dear Gurdev Dhijan:

**Re: Application for Approval
Industrial Holding Tank Servicing 11 Shannon Court
Amaranth Township, County of Dufferin
Reference Number 4337-DC8RTL**

Dear Mr. Gurdev Dhijan,

The ministry has reviewed the application Reference No. 4337-DC8RTL for the All Start Precast location at 11 Shannon Court, Township of Amaranth, County of Dufferin.

The application pertains to use of a Holding Tank to service concrete wash water generated from manufacturing of precast concretes products. Following a thorough review, the ministry has determined that the proposed sewage works do not fall under the *Ontario Water Resources Act* (OWRA) Section 53 ECA requirements.

The Holding Tank meets the OWRA Section 53 (6)(a) exemption for a sewage works from which sewage is not to drain or be discharged directly or indirectly into a ditch, drain or storm sewer or a well, lake, river, pond, spring, stream, reservoir or other water or watercourse. It is not required to have an ECA under Section 53 (6.1) of the OWRA as the design capacity of the sewage works is not more than 10,000 litres per day. As such, a sewage works ECA is not required for the use, operation, establishment, alteration, extension or replacement of the Holding Tank proposed in the ECA application.

It is the ministry's understanding that All Start Precast has characterised the concrete wash water, obtained the necessary registration (manifestation), and uses an approved waste hauler to transport the waste concrete wash water to an approved ministry waste disposal site. In accordance with Section 17.1 of Regulation 347, a waste ECA is also not required for the

collection and storage of concrete wash water at the facility.

The submitted application fee will be refunded shortly in the amount of \$6000.0 which represents the amount submitted reduced by the non-refundable administrative processing fee of \$200.

If you have any questions regarding the above, please contact Mohammed Nizamuddin, Senior Wastewater Engineer at (416) 314-7998.

Yours truly,

Fariha Pannu, P.Eng.

Director

appointed for the purposes of Part II.1 of the *Environmental Protection Act*

MN/

c: District Manager, MECP Guelph

Jackie Coughlin, Azimuth Environmental Consulting Inc.