

AMENDED ENVIRONMENTAL COMPLIANCE APPROVAL

NUMBER 9606-DWENUJ

Issue Date: September 3, 2026

AOC RESINS AND COATINGS COMPANY
38 Royal Rd
Guelph, Ontario
N1H 1G3

Site Location: 38 Royal Road
City of Guelph, County of Wellington

You have applied under section 20.2 of Part II.1 of the Environmental Protection Act , R.S.O. 1990, c. E. 19 (Environmental Protection Act) for approval of:

existing stormwater management Works servicing the approximately 4.6 hectare manufacturing facility, for the collection, transmission, treatment and disposal of stormwater runoff, to provide quality improvements and to attenuate post-development peak flow to allowable release rates, discharging to municipal roadside ditches on Royal Road and Massey Road, consisting of the following:

Existing Works:

rooftop storage (catchment area 0.197 ha) for the building addition, having an available storage volume of 197 cubic metres at a maximum storage depth of 0.1 m, discharging via onsite storm sewers to the oil/grit separator (Wilkinson Model 12) identified below;

oil/grit separator (catchment area 1.34 ha), model Wilkinson Model 12, receiving stormwater from the building addition rooftop runoff and parking lot runoff, discharging via a 450 mm storm sewer to the roadside ditches on Royal Road;

rooftop storage (catchment area 0.644 ha) for the main plant building, having an available storage volume of 644 cubic metres at a maximum storage depth of 0.1 m, discharging via onsite storm sewers to the existing dry pond identified below;

grass bottomed dry pond (catchment area 3.11 ha), equipped with a sediment forebay, having an available storage volume of 1,124 cubic metres at a maximum depth of 1.37 m, receiving stormwater runoff from main existing onsite storm sewers and overflows from the Fire Retention ponding area, discharging via a 250 mm diameter outlet pipe to the roadside ditches on Royal Road;

Fire Retention ponding area (disconnected and no longer used for fire fighting purposes), receiving stormwater surface runoff from adjacent areas, having an available storage capacity of 425 cubic metres for infiltration and evaporation, with overflows directed to the existing grass bottomed dry pond identified above;

Existing Works - Containment Area:

a concrete-lined, trapezoidal cross-section West Lagoon, capable of holding 373 cubic metres, extending for a distance of about 107 metres along the western plant fence line, with an approximately 3.7 metre wide sloping floor, a 1.4 metre perpendicular west wall and a shorter, sloped east wall to collect overland surface storm run-off from the plant area, and convey it through a north wall discharge pipe with a manually operated outlet flow shut-off valve (normally closed - opened only under supervision) to a built-in concrete oil separator compartment;

one (1) oil separator compartment, measuring 3.7 metres by 1.2 metres by 2.7 metres deep with an approximate oil holding volume of 1.5 cubic metres and a maximum design flow rate of 1.6 cubic metres per minute, discharging through a bottom fed pipe to an adjacent built-in concrete sump compartment connected to an underground culvert which discharges to a municipal storm ditch along Massey Road and ultimately to the Speed River;

five (5) concrete-lined containment areas described below for collecting storm water and any process material spills, with the described tie-ins allowing the transfer of collected material to the West Lagoon:

- The Dowtherm Containment Area consisting of a 15.2 metre by 13.0 metre concrete pad, sloped toward a central, concrete sump, with an overall pad containment volume of approximately 18.1 cubic metres tied-in to the Rail Car Unloading Area containment basin, on an "as needed basis" by means of a dedicated portable pump, rated at 1.2 cubic metres per minute, and dedicated lengths of 51 millimetre diameter rubber hose,
- The Rail Car Unloading Area consisting of a reinforced concrete slab, approximately 48.5 metres by 13.2 metres, sloped toward a 9.1 metre by 18.5 metre by 0.61 metre deep containment basin providing a containment volume of approximately 103.5 cubic metres which is tied into the West Lagoon by means of a 76 millimetre stainless steel pipe and a manually operated ball valve (normally closed),

- The Anhydride Containment Area consisting of a 17.6 metre by 20.3 metre reinforced concrete slab surrounded by a 0.9 metre concrete wall on three sides and a 1.1 metre wall on the fourth side, with a 2.6 metre by 17.7 metre curbed, concrete-lined pump pad on one side with drainage openings to the containment area, and a 4.5 metre by 17.6 metre long sloped concrete apron adjacent to the pump pad, providing an overall containment volume of approximately 300 cubic metres, which is tied into the West Lagoon by means of a 50 millimetre stainless steel pipe and a manually operated ball valve (normally closed),
- The Flammable Liquid Storage Containment Area consisting of a 15.9 metre square concrete pad surrounded by a 0.91 metre concrete wall on three sides and a 1.1 metre wall on the fourth side, with a 2.6 metre by 15.9 metre curbed, concrete-lined pump pad on one side with drainage openings to the containment area, and a 4.3 metre wide, sloped concrete apron on two sides of the pad, providing an overall containment volume of approximately 220 cubic metres, to direct any contained spills or storm water to a central collection trench which is tied into the West Lagoon by means of a 76 millimetre stainless steel pipe and a manually operated ball valve (normally closed),
- The Finished Products Loading Containment Area consisting of a collection trench between a 14.8 metre by 28.0 metre sloped concrete pad on one side and a smaller 4.1 metre by 13.9 metre sloped pad on the other, providing an overall containment volume of approximately 49.4 cubic metres with a tie-in from the collection trench to the West Lagoon by means of a 76 millimetre stainless steel pipe and a manually operated ball valve (normally closed).

all in accordance with the all supporting documentation and information submitted to the Ministry as listed in the Schedule A in this Approval.

For the purpose of this environmental compliance approval, the following definitions apply:

1. "Approval" means this entire Environmental Compliance Approval and any Schedules attached to it;
2. "Director" means a person appointed by the Minister pursuant to section 5 of the

EPA for the purposes of Part II.1 of the EPA;

3. "District Manager" means the District Manager of the appropriate local District Office of the Ministry, where the Works are geographically located;
4. "EPA" means the *Environmental Protection Act*, R.S.O. 1990, c.E.19, as amended;
5. "Existing Works" means those portions of the Works included in the Approval that have been constructed previously;
6. "Licensed Engineering Practitioner" means a person who holds a licence, limited licence or temporary licence under the *Professional Engineers Act*, R.S.O. 1990, c. P.28;
7. "Ministry" means the ministry of the government of Ontario responsible for the EPA and OWRA and includes all officials, employees or other persons acting on its behalf;
8. "Owner" means AOC RESINS AND COATINGS COMPANY and its successors and assignees;
9. "OWRA" means the *Ontario Water Resources Act*, R.S.O. 1990, c. O.40, as amended;
10. "Works" means the approved sewage works, and includes Existing Works.

You are hereby notified that this environmental compliance approval is issued to you subject to the terms and conditions outlined below:

TERMS AND CONDITIONS

1. GENERAL PROVISIONS

1. The Owner shall ensure that any person authorized to carry out work on or operate any aspect of the Works is notified of this Approval and the terms and conditions herein and shall take all reasonable measures to ensure any such person complies with the same.
2. The Owner shall design, construct, operate and maintain the Works in accordance with the conditions of this Approval.
3. Where there is a conflict between a provision of any document referred to in this Approval and the conditions of this Approval, the conditions in this Approval shall take precedence.
4. The issuance of, and compliance with the conditions of, this Approval does not:

- a. relieve any person of any obligation to comply with any provision of any applicable statute, regulation or other legal requirement, including, but not limited to, the obligation to obtain approval from the local conservation authority necessary to construct or operate the Works; or
- b. limit in any way the authority of the Ministry to require certain steps be taken to require the Owner to furnish any further information related to compliance with this Approval.

2. CHANGE OF OWNER

1. The Owner shall notify the District Manager and the Director, in writing, of any of the following changes within **thirty (30) days** of the change occurring:
 - a. change of address of Owner;
 - b. change of Owner, including address of new owner;
 - c. change of partners where the Owner is or at any time becomes a partnership, and a copy of the most recent declaration filed under the *Business Names Act, R.S.O. 1990, c. B.17* shall be included in the notification; or
 - d. change of name of the corporation, and a copy of the most current information filed under the *Corporations Information Act, R.S.O. 1990, c. C39* shall be included in the notification.
2. In the event of any change in ownership of the Works, the Owner shall notify in writing the succeeding owner of the existence of this Approval, and a copy of such notice shall be forwarded to the District Manager and the Director.
3. The Owner shall ensure that all communications made pursuant to this condition refer to the number of this Approval.

3. RECORD DRAWINGS

1. A set of record drawings of the Works shall be kept up to date through revisions undertaken from time to time and a copy shall be readily accessible for reference at the Works.

4. OPERATION AND MAINTENANCE

1. The Owner shall make all necessary investigations, take all necessary steps and obtain all necessary approvals so as to ensure that the physical structure, siting and operations of the Works do not constitute a safety, health or flooding hazard to the general public.

2. The Owner shall undertake an inspection of the condition of the Works, at least once a year, and undertake any necessary cleaning and maintenance to ensure that sediment, debris and excessive decaying vegetation are removed from the Works to prevent the excessive build-up of sediment, oil/grit, debris and/or decaying vegetation, to avoid reduction of the capacity and/or permeability of the Works, as applicable. The Owner shall also regularly inspect and clean out the inlet to and outlet from the Works to ensure that these are not obstructed.
3. The Owner shall construct, operate and maintain the Works with the objective that the effluent from the Works is essentially free of floating and settleable solids and does not contain oil or any other substance in amounts sufficient to create a visible film, sheen, foam or discoloration on the receiving waters.
4. The Owner shall carry out and maintain an inspection and maintenance program on the operation of the manhole oil/grit separator in accordance with the manufacturer's recommendation.
5. The Owner shall ensure that the manhole for the oil/grit separator remains accessible year-round to facilitate maintenance access and spill response measures.
6. The Owner shall ensure the immediate clean-out of the Works after a fuel or oil spill capture.
7. The Owner shall ensure that equipment and material for the containment, clean-up and disposal of process materials, fuel and oil and materials contaminated with such, is on hand and in good repair for immediate use in the event of:
 - a. loss of fuel or oil to the Works; or
 - b. loss of process materials from plant equipment;
 - c. a spill within the meaning of Part X of the EPA;
 - d. the identification of an abnormal amount of process materials in the containment areas, the oil/water separator or the West Lagoon.
8. The Owner shall prepare an operations manual prior to the commencement of operation of the Works that includes, but is not necessarily limited to, the following information:
 - a. operating and maintenance procedures for routine operation of the Works;

- b. inspection programs, including frequency of inspection, for the Works and the methods or tests employed to detect when maintenance is necessary;
 - c. repair and maintenance programs, including the frequency of repair and maintenance for the Works;
 - d. contingency plans and procedures for dealing with potential abnormal situations and for notifying the District Manager; and
 - e. procedures for receiving, responding and recording public complaints, including recording any follow-up actions taken.
9. The Owner shall maintain an up to date operations manual and make the manual readily accessible for reference at the Works for the operational life of the Works. Upon request, the Owner shall make the manual available to Ministry staff.
10. The Owner shall maintain a logbook to record the results of these inspections and any cleaning and maintenance operations undertaken, and shall keep the logbook at the Works for inspection by the Ministry. The logbook shall include the following:
- a. the name of the Works;
 - b. the date and results of each inspection, maintenance and cleaning, including an estimate of the quantity of any materials removed and method of clean-out of the Works; and
 - c. the date of each spill within the catchment area, including follow-up actions and remedial measures undertaken.
11. The Owner shall retain for a minimum of **five (5) years** from the date of their creation, all records and information related to or resulting from the operation and maintenance activities required by this Approval.

5. OPERATION AND MAINTENANCE - CONTAINMENT AREAS AND WEST LAGOON

1. The Owner shall inspect the containment areas, the West Lagoon and the oil separator on a weekly basis and keep a log or record of the inspections at the plant.
2. The West Lagoon outlet flow shut-off valve shall normally be closed but it may be opened to discharge the stored batch contents of the West Lagoon,

provided that the batch parameter concentrations, shown in the Table 2 in Schedule B are not exceeded, and no transfers to the West Lagoon are made from any of the containment areas while the West Lagoon outlet flow shut-off valve is open.

3. Following the discharge of each batch tested, the West Lagoon outlet flow shut-off valve is to be closed.
4. The Owner shall undertake everything practicable to identify and immediately clean up all losses of process materials which can drain to the containment sumps or to the West Lagoon.
5. The Owner shall, upon identification of a loss of process materials, take immediate action to prevent the further occurrence of such loss.
6. The Owner shall keep an operational log documenting all containment area analytical results, transfer dates, lagoon discharge dates and lagoon batch analyses including the approximate volumes of each transfer and discharge.

6. EFFLUENT OBJECTIVES

1. The Owner shall undertake everything practicable to operate the Works such that the concentrations of the materials named in Table 1 of Schedule B for each containment area are not exceeded prior to transfer of the materials either to the Rail Car Unloading Area for Dowtherm Area transfers or to the West Lagoon for the other four containment area transfers.
2. Notwithstanding any other Condition in this Approval, the Owner shall undertake everything practicable to ensure that the contents transferred from any of the containment areas for discharge from the West Lagoon are free from noticeable odour, surface sheen and milky haze.
3. The Owner shall undertake everything practicable to operate the Works such that the concentrations of materials named in Table 2 of Schedule B as effluent parameters are not exceeded in the effluent from the West Lagoon.
4. In the event of an exceedance of the objective set out in subsection 3, the Owner shall:
 - a. notify the District Manager as soon as possible during normal working hours;
 - b. take immediate action to identify the source of contamination; and
 - c. take immediate action to prevent further exceedance.
5. Notwithstanding any other Condition in this Approval, the Owner shall ensure

that the effluent from the Works is essentially free of floating and settleable solids and noticeable odour, and does not contain oil or any other substance in amounts sufficient to create a visible film or sheen or foam on the receiving waters.

7. EFFLUENT MONITORING

1. The Owner shall ensure that all samples and measurements taken for the purposes of this Approval are to be taken at a time and in a location characteristic of the quality and quantity of the effluent stream over the time period being monitored.
2. Prior to the discharge of each batch from the West Lagoon, the Owner shall sample the Lagoon contents by taking three grab samples, one from each of three locations along the West Lagoon (south end, middle portion and north end) and analyze the samples, either combined or individually, as allowed under subsection 5, for the parameters listed in **Table 1 of Schedule C**.
3. Prior to the transfer of each collected batch of material from any one of the five containment areas, named in **Table 2 of Schedule C**, for eventual discharge from the West Lagoon, the Owner shall ensure that the West Lagoon outlet valve is closed and also take a grab sample of the contents to be transferred and analyze the sample for the parameters indicated by the "x" marks in the column for the appropriate containment area, in accordance with **Table 2 of Schedule C**.
4. The monitoring requirements as described under subsection 2 and 3 may be changed to such frequency as the District Manager may specify in writing from time to time.
5. The methods and protocols for sampling, analysis, toxicity testing, and recording shall conform, in order of precedence, to the methods and protocols specified in the following:
 - a. the Ministry's publication "Protocol for the Sampling and Analysis of Industrial/Municipal Wastewater Version 2.0" (January 2016), PIBS 2724e02, as amended from time to time by more recently published editions;
 - b. the publication "Standard Methods for the Examination of Water and Wastewater" (21st edition) as amended from time to time by more recently published editions;
 - c. for any parameters not mentioned in the documents referenced in Paragraphs 3.a and 3.b, the written approval of the District Manager shall be obtained prior to sampling.

6. The Owner shall retain for a minimum of **five (5) years** from the date of their creation, all records and information related to or resulting from the monitoring activities required by this Approval.

8. REPORTING

1. The Owner shall, upon request, make all reports, manuals, plans, records, data, procedures and supporting documentation available to Ministry staff.
2. In addition to the obligations under Part X of the EPA and O. Reg. 675/98 (Classification and Exemption of Spills and Reporting of Discharges) made under the EPA, the Owner shall, within **fifteen (15) days** of the occurrence of any reportable spill as provided in Part X of the EPA and O. Reg. 675/98, submit a full written report of the occurrence to the District Manager describing the cause and discovery of the spill, clean-up and recovery measures taken, preventative measures to be taken and a schedule of implementation.
3. The Owner shall prepare performance reports on a calendar year basis and submit to the District Manager no later than 60 days following year-end. The reports shall contain, but shall not be limited to, the following information pertaining to the reporting period, in a format acceptable to the District Manager:
 - a. a summary and interpretation of all monitoring data, including an overview of the success and adequacy of the Works;
 - b. a description of any operating problems encountered and corrective actions taken;
 - c. a summary of all maintenance carried out on any major structure, equipment, apparatus, mechanism or thing forming part of the Works, including an estimate of the quantity of any materials removed from the Works;
 - d. the analytical data for each batch transferred from the containment areas and for each batch discharged from the West Lagoon, including the total number of transfers and discharges, their approximate volume and frequency.
 - e. a summary of the calibration and maintenance carried out on all effluent monitoring equipment;
 - f. a summary of any effluent quality assurance or control measures undertaken in the reporting period;
 - g. a description of efforts made and results achieved in

meeting the Effluent Objectives of Condition 6.

- h. a summary of any complaints received during the reporting period and any steps taken to address the complaints;
- i. a summary of all spill or abnormal discharge events; and
- j. any other information the District Manager requires from time to time.

4. The Owner shall submit the performance report required under subsection 4 to the Grand River Source Protection Authority and City of Guelph within fifteen (15) days of submission to the District Manager.

The reasons for the imposition of these terms and conditions are as follows:

1. Condition 1 is imposed to ensure that the Works are constructed and operated in the manner in which they were described and upon which approval was granted. This condition is also included to emphasize the precedence of conditions in the Approval and the practice that the Approval is based on the most current document, if several conflicting documents are submitted for review. Condition 1.4 is included to emphasize that the issuance of this Approval does not diminish any other statutory and regulatory obligations to which the Owner is subject in the construction, maintenance and operation of the Works. The Condition specifically highlights the need to obtain any necessary conservation authority approvals. The Condition also emphasizes the fact that this Approval doesn't limit the authority of the Ministry to require further information.
2. Condition 2 is included to ensure that the Ministry records are kept accurate and current with respect to the approved Works and to ensure that subsequent owners of the Works are made aware of the Approval and continue to operate the Works in compliance with it.
3. Condition 3 is included to ensure that the Works are constructed in accordance with the approval and that record drawings of the Works "as constructed" are maintained for future references.
4. Condition 4 and 5 are included as regular inspection and necessary removal of sediment and excessive decaying vegetation from the Works are required to mitigate the impact of sediment, debris and/or decaying vegetation on the treatment capacity of the Works. The Condition also ensures that adequate storage is maintained in the Works at all times as required by the design. Furthermore, this Condition is included to ensure that the Works are operated and

maintained to function as designed.

5. Condition 6 is imposed to establish non-enforceable effluent quality objectives which the Owner is obligated to use best efforts to meet on an ongoing basis. Also imposed are procedures to be followed to minimize environmental impact in the event the objectives are exceeded.
6. Condition 7 is included to require the Owner to demonstrate on a continual basis that the quality and quantity of the effluent from the approved Works is consistent with the design and effluent objectives specified in the Approval and that the approved Works does not cause any impairment to the receiving watercourse.
7. Condition 8 is included to provide a performance record for future references, to ensure that the Ministry is made aware of problems as they arise, and to provide a compliance record for all the terms and conditions outlined in this Approval, so that the Ministry can work with the Owner in resolving any problems in a timely manner.

Schedule A

1. Environmental Compliance Approval Application for Industrial Sewage Works dated May 9, 2025 including all supporting documentation and information.
2. Application for Approval of Industrial Sewage Works dated April 19, 2001 and signed by Stephanie Kibbee, Safety/Environmental Specialist, AOC Canada Inc., including all supporting documentation and information.
3. Application for Approval of Industrial Sewage Works dated September 3, 1997 and signed by William Van Veen, Plant Manager, Alpha-Owens Corning (Canada) Inc., (AOC Canada Inc.), including all supporting documentation and information.

Schedule B

Table 1 - Maximum Allowable Parameter Concentrations for each Containment Area Batch Transfers For West Lagoon Discharge (µg/L unless otherwise noted)

Effluent Parameter	Dowtherm	Rail Car Unloading	Flammable Liquid Storage	Anhydride	Finished Products
Styrene	-	8	8	-	8
Toluene	-	1.6	1.6	-	1.6
o-Xylene	-	80	80	-	80
m- and p-Xylene	-	60	60	-	60
Diphenyl Ether	0.06	-	-	-	-
DOC	25 mg/L	25 mg/L	25 mg/L	25 mg/L	25 mg/L

Table 2 - Effluent Objectives Table (measured at the discharge outlet from the West Lagoon)

Effluent Parameter	Concentration Objective
Styrene	8 µg/L
Toluene	1.6 µg/L
o-Xylene	80 µg/L
m- and p-Xylene	60 µg/L
Diphenyl Ether	0.06 µg/L
DOC	25 mg/L
Oil & Grease	15 mg/L
Total Suspended Solids	25 mg/L
pH	between 6.0 and 9.5 inclusive

Schedule C

Table 1 - Effluent Monitoring Table for the West Lagoon

Sample Type	Three (3) grab samples, one for each of three locations along the West Lagoon (south end, middle portion and north end)
Monitoring Frequency	Batch volume of effluent collected in the West Lagoon from surface run-off or from transfers from the containment areas while the Lagoon outlet flow shut-off valve has been shut.
Effluent Parameters	Styrene, Toluene, o-Xylene, m- and p-Xylene, Diphenyl Ether, DOC, Oil & Grease, Total Suspended Solids, pH

**Table 2 - Effluent Monitoring Table for the Containment Areas
(Prior to transfer of each collected batch of material - See Condition 7.3)**

Effluent Parameter	Dowtherm	Rail Car Unloading	Flammable Liquid Storage	Anhydride	Finished Products
Styrene	-	Grab	Grab	-	Grab
Toluene	-	Grab	Grab	-	Grab
o-Xylene	-	Grab	Grab	-	Grab
m- and p-Xylene	-	Grab	Grab	-	Grab
Diphenyl Ether	Grab	-	-	-	-
DOC	Grab	Grab	Grab	Grab	Grab

Upon issuance of the environmental compliance approval, I hereby revoke

Approval No(s). 5711-BX2TTQ issued on January 26, 2021.

In accordance with Section 139 of the *Environmental Protection Act*, you may by written notice served upon me, the Ontario Land Tribunal and in accordance with Section 47 of the *Environmental Bill of Rights*, 1993, the Minister of the Environment, Conservation and Parks, within 15 days after receipt of this notice, require a hearing by the Tribunal. The Minister of the Environment, Conservation and Parks will place notice of your appeal on the Environmental Registry. Section 142 of the *Environmental Protection Act* provides that the notice requiring the hearing ("the Notice") shall state:

- a. The portions of the environmental compliance approval or each term or condition in the environmental compliance approval in respect of which the hearing is required, and;
- b. The grounds on which you intend to rely at the hearing in relation to each portion appealed.

Pursuant to subsection 139(3) of the *Environmental Protection Act*, a hearing may not be available with respect to any terms and conditions in this environmental compliance approval, if the terms and conditions are substantially the same as those contained in an approval that is amended or revoked by this environmental compliance approval.

The Notice should also include:

1. The name of the appellant;
2. The address of the appellant;
3. The environmental compliance approval number;
4. The date of the environmental compliance approval;
5. The name of the Director, and;
6. The municipality or municipalities within which the project is to be engaged in.

And the Notice should be signed and dated by the appellant.

This Notice must be served upon:

Registrar*
Ontario Land Tribunal
655 Bay Street, Suite 1500
Toronto, Ontario
M5G 1E5
OLT.Registrar@ontario.ca

and

The Minister of the Environment,
Conservation and Parks
777 Bay Street, 5th Floor
Toronto, Ontario
M7A 2J3

and

The Director appointed for the purposes of
Part II.1 of the *Environmental Protection Act*
Ministry of the Environment, Conservation
and Parks
40 St. Clair Avenue West, 2nd Floor
Toronto, Ontario
M4V 1M2

*** Further information on the Ontario Land Tribunal's requirements for an appeal can be obtained directly from the Tribunal at: Tel: (416) 212-6349 or 1 (866) 448-2248, or www.olt.gov.on.ca**

This instrument is subject to Section 38 of the *Environmental Bill of Rights*, 1993, that allows residents of Ontario to seek leave to appeal the decision on this instrument. Residents of Ontario may seek leave to appeal within 15 days from the date this decision is placed on the

Environmental Registry. By accessing the Environmental Registry at <https://ero.ontario.ca/>, you can determine when the leave to appeal period ends.

The above noted activity is approved under s.20.3 of Part II.1 of the *Environmental Protection Act*.

DATED AT TORONTO this 3rd day of September,
2026

Fariha Pannu, P.Eng.
Director
appointed for the purposes of Part II.1 of the
Environmental Protection Act

JY/
c: District Manager, MECP Guelph
Steve Conway, GEI Consultants Canada Ltd.