Proposed change: 1418

Support: I support this proposed change with modification(s).

Reason:

Current:
[2.2.1.14.] --- Fabrics and Films
[1] --) Fabrics and films used in connection with tents and air-supported structures shall conform to CAN/ULC-S109, "Flame Tests of Flame-Resistant Fabrics and Films."

Proposed:
[2.2.1.14.] --- Fabrics and Films
[1] --) Fabrics and films used in connection with FABRIC COVERED BUILDINGS shall conform to CAN/ULC-S109, "Flame Tests of Flame-Resistant Fabrics and Films."

Reasoning:
The intent based on discussion with members of the joint task force was to target "fabric covered buildings" such as Cover-all, Brite-span, etc. The structures defined as "tents and air-supported" are not farm buildings and are covered elsewhere in the NBC.