Proposed change: 1418

Support: I support this proposed change with modification(s).

Reason:

[2.2.1.8.] --- Fire Blocks
[5] --) Fire blocks need not be tested in conformance with Sentence (4) if they are constructed of not less than
[a] --) 0.38 mm sheet steel,
[b] --) 12.7 mm gypsum board,
[c] --) 12.5 mm plywood, OSB or waferboard, with joints backed with similar material,

PROPOSED:
[2.2.1.8.] --- Fire Blocks
[5] --) Fire blocks need not be tested in conformance with Sentence (4) if they are constructed of not less than
[a] --) 0.38 mm sheet steel,
[b] --) 12.7 mm gypsum board,
[c] --) 12.5 mm plywood, 11.1 mm OSB or waferboard, with joints backed with similar material,

Reasoning:

7/16" (11.1mm) panel thickness is a more commonly used and readily available building material for OSB sheathing.