



THE TOWNSHIP OF
WOOLWICH

BOX 158, 24 CHURCH ST. W.
ELMIRA, ONTARIO N3B 2Z6
TEL. 519-669-1647 / 1-877-969-0094
DEVELOPMENT SERVICES FAX 519-669-4669

February 28, 2024

Dear Sir / Madam

RE:

Notification of Application for Permit to Take Water

Ministry Reference Number: 1000267488

Applicant: Capital Paving Inc.

Location of Water Taking(s): 1195 Foerster Road, Breslau

Permit Type: Category 3, New

The Township received the above notice regarding the proposed water taking.

The Township has no objection to the above noted water taking but notes that the operation is subject to an Ontario Land Tribunal (OLT) decision (attached) and the associated MNRF approved license.

The MNRF license contains various requirements with respect to the operations of the site, including the hydrogeological requirements and the use of wash ponds, associated operations, as well as regular monitoring (including nearby wells). Water taking should be consistent with reports submitted for the extraction operation, where the wash pond is to be a closed loop system, where the pond cannot exceed 0.25 hectares and the water source for the pond is from precipitation and from the intersecting the water table (no well or pumping from other sources on site).

We request that any decision with respect to this water taking be consistent with the OLT decision.

Yours truly,

Jeremy Vink
Manager of Planning
Township of Woolwich

Attach.